



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/18/2024

SUBJECT: SFD2311-0050
SINGLE FAMILY DWELLING

To: Kenneth McGlothlin Construction Inc

Here are the results of all Inspections located at **916 SPRING HILL CHURCH RD:**

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 11/21/2023
Completed Date/Time: 11/22/2023
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 916 SPRING HILL CHURCH RD LILLINGTON 27546.





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 12/14/2023
Completed Date/Time: 12/14/2023
Inspector: John B Kokoszka
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/13/2023 11:58 AM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com

Inspection Type: FOUNDATION
Scheduled Date/Time: 12/29/2023
Completed Date/Time: 12/29/2023
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/27/2023 9:18 AM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 1/8/2024
Completed Date/Time: 1/8/2024
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/5/2024 1:58 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 1/23/2024
Completed Date/Time: 1/23/2024
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/22/2024 1:06 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com

Shower surround leak. Leaking coupling at kitchen sink. Need outlet within 24 inch of sink. Missing gable brace on porch. Tape vertical seams in housewrap. Missing flashing for back porch.

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 1/25/2024
Completed Date/Time: 1/25/2024
Inspector: John B Kokoszka
Result: APPROVED W/EXC
Remarks: eTRAKiT Inspection Request
Notes: 1/23/2024 4:29 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com

Need to see shower pan test after it gets fixed



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 1/25/2024
Completed Date/Time: 1/25/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/23/2024 4:29 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time: 2/6/2024
Completed Date/Time: 2/6/2024
Inspector: Mark Osborne
Result: APPROVED
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 2/14/2024
Completed Date/Time: 2/14/2024
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 2/13/2024 4:04 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 2/14/2024
Completed Date/Time: 2/14/2024
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 2/13/2024 4:04 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 2/22/2024
Completed Date/Time: 2/22/2024
Inspector: James T Hall
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 2/21/2024 12:28 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com

Missing receptacle in right front bedroom behind door
Missing disconnect for condensing unit

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 2/26/2024
Completed Date/Time: 2/26/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 2/23/2024 1:00 PM Kenneth McGlothlin Construction Inc

Contact Name: Kenneth McGlothlin Construction Inc
Site Address: 916 SPRING HILL CHURCH RD
Phone: 9196697026
e-Mail: kmcinc.kenneth@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 5/8/2024
Completed Date/Time: 5/8/2024
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time: 5/8/2024
Completed Date/Time: 5/8/2024
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes: