



# ROOF & FLOOR TRUSSES & BEAMS

Reilly Road Industrial Park  
Fayetteville, N.C. 28309  
Phone: (910) 864-8787  
Fax: (910) 864-4444


Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables ( derived from the prescriptive Code requirements ) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature **Johnnie Baggett**  
**Johnnie Baggett**

### LOAD CHART FOR JACK STUDS

(BASED ON TABLES R502.5(1) & (b))

NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER		
END REACTION (UP TO)	REQ. STUDS FOR (1) 1/2" HEADER	REQ. STUDS FOR (1) 1/2" HEADER
1700	1	3400
3400	2	5100
5100	3	6800
6800	4	8500
8500	5	10200
10200	6	11900
11900	7	13600
13600	8	15300
15300	9	



**Dimension Notes**  
1. All exterior wall to wall dimensions are to face of sheathing unless noted otherwise  
2. All interior wall dimensions are to face of stud unless noted otherwise  
3. All exterior wall to truss dimensions are to face of stud unless noted otherwise

Roof Area = 2642.43 sq.ft.  
Ridge Line = 69.29 ft.  
Hip Line = 20.11 ft.  
Horiz. OH = 165.27 ft.  
Raked OH = 187.52 ft.  
Decking = 91 sheets

All Walls Shown Are Considered Load Bearing

▲ = Indicates Left End of Truss (Reference Engineered Truss Drawing)  
Do Not Erect Trusses Backwards

**WALL SCHEDULE**

- 1st Floor Walls
- 2nd Floor Walls
- Non-Bearing Walls
- Garage Walls Dropped

**Products**

PlotID	Length	Product	Plies	Net Qty
FB1	13' 0"	1-3/4"x 14" LVL Kerto-S	3	3
FB2	11' 0"	1-3/4"x 14" LVL Kerto-S	2	2

Connector Information					Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Header	Truss
■	HUS26	USP	9	NA	16d/3-1/2"	16d/3-1/2"
■	JUS24	USP	13	NA	10d/3"	10d/3"
■	HJC26	USP	2	Varies	16d/3-1/2"	10d/3"

Truss Placement Plan  
SCALE: NTS

▲ = Indicates Left End of Truss  
(Reference Engineered Truss Drawing)  
Do NOT Erect Truss Backwards

BUILDER	CITY / CO.	ADDRESS	MODEL	DATE REV.	DRAWN BY	SALES REP.
New Home Inc	Lillington / Harnett	1723 Neills Creek Road	Roof	11/11/23	Johnnie Baggett	Johnnie Baggett
JOB NAME	Lot 1A Heritage at Neill's Cre					
PLAN	The Selma - Traditional					
SEAL DATE	Seal Date					
QUOTE #	Quote #					
JOB #	J1023-5899					

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com