## Harnett County Inspections Department

## 3RD PARTY INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information: Residential

Single Family Project: Code Enforcement

Commercial Project:

N

Project No.:

Project Name: 11 KEITH WEATHERS RD

FUQUAY VARINA, NC

Permit No.: Owner: MARY **NELL BRADLEY HAMILTON** 

Suite No .:

Contractor Name:

CASTTON CONSTRUCTION

Project Address: 11 KEITH WEATHERS RD FUQUAY VARINA, NC

Date Inspected: FEBRUARY 22, 2024 Component Inspected: FOOTING

Responsible Licensed NC Architect or NC Engineer

Name: JOE E GODWIN, SR

Firm Name: ENOCH ENGINEERS, PA Phone No.: Office 919-894-7765

Email Address: JASON@ENOCHENGINEERS.COM

Mobile

Mailing Address: 1403 NC HWY 50 S, BENSON NC 27504

919-820-3491

APPLICABLE CODE SECTION:

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: \*

2018 NC Residential Code, Section 403

Residential footing size, depth, placement and bearing capacity of 2,000 psf were confirmed onsite. Our inspection confirmed conformance with the above 2018 NC Building code. In addition, our inspection was performed in accordance with the approved jobsite CDs.

\*(subgrade form/letter may also be required) Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional decuments if needed

LICENSED ARCHITECT OR ENGINE

Inspection Departmen disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.