

Dimension Notes All exterior wall to wall dimensions are to face of sheathing unless noted otherwise
 All interior wall dimensions are to face of stud unless noted otherwise
 All exterior wall to truss dimensions are to face of stud unless noted otherwise

Roof Area = 2439.98 sq.ft. Ridge Line = 63.04 ft. Hip Line = 23.76 ft. Horiz. OH = 142.07 ft. Raked OH = 170.9 ft. Decking = 84 sheets

All Walls Shown Are Considered Load Bearing

▲ = Indicates Left End of Truss (Reference Engineered Truss Drawing) Do Not Erect Trusses Backwards

WALL SCHEDULE
1st Floor Walls
2nd Floor Walls
□□□□□ Non-Bearing Walls
Garage Walls Dropped

	Conne	Nail Information				
Sym	Product	Manuf	Qty	Supported Member	Header	Truss
	HUS26	USP	9	NA	16d/3-1/2"	16d/3-1/2"
	JUS24	USP	8	NA	10d/3"	10d/3"



Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444

Bearing reactions less than or equal to 3000# are leemed to comply with the prescriptive Code equirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code equirements) to determine the minimum foundation size and number of wood studs required to support eactions greater than 3000# but not greater than 15000#. A registered design professional shall be etained to design the support system for any eaction that exceeds those specified in the attached Tables. A registered design professional shall be etained to design the support system for all eactions that exceed 15000#.

Signature Johnnie Baggett

Johnnie Baggett

LOAD CHART FOR JACK STUDS (BASED ON TABLES R502.5(1) & (b))

	(B	MOED C	IN IMPLES	S KUUZ.	.υ(1) α (t)))	
NU	MBER C	F JACI	STUDS R			A END OF	•
END REACTION (UP TO)	REQ'D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR
1700	1		2550	1		3400	1
3400	2		5100	2		6800	2
5100	3		7650	3		10200	3
6800	4		10200	4		13600	4
8500	5		12750	5		17000	5
10200	6		15300	6			
11900	7						
13600	8						
15300	9						

CITY / CO.	CITY / CO. Harnett / Lillington
ADDRESS	367 Duncans Creek Road
WODEL	Roof
DATE REV.	10/14/24
DRAWN BY	Johnnie Baggett
SALES REP	SALES REP. Paul Hawkins

JOB NAME SEAL DATE **QUOTE** # THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

B0824-4380

New Home Inc

BUILDER