



ALTERNATE INSPECTIONS FOR LP GAS PIPINGSYSTEM FOR RESIDENTIAL  
STRUCTURES

April 5, 2024

To: Harnett County Inspections

From: Hunter Oil and Propane, Lic. # 22196

**RE: 187 Golden Leaf Farms Rd Angier NC**

Please be advised that we hereby certify that 25 feet of LP gas line was buried at or below the minimum depth required by North Carolina Code #404.12 Minimum Burial Depth. In addition we also hereby certify that approved materials were used and the line was pressurized to 65 PSI for 45 minutes in accordance with NC GS 143-139.3. Inspection of LPG 2417.1.

A handwritten signature in black ink, appearing to be "A. H. B.", is written over a horizontal line.

Signed by Licensed Contractor performing work



ALTERNATE INSPECTIONS FOR LP GAS PIPING SYSTEM FOR RESIDENTIAL  
STRUCTURES

April 5, 2024

To: Harnett County Inspections

From: Hunter Oil and Propane, Lic. # 22196

**RE: 60 Harvester Rd Angier NC**

Please be advised that we hereby certify that 25 feet of LP gas line was buried at or below the minimum depth required by North Carolina Code #404.12 Minimum Burial Depth. In addition we also hereby certify that approved materials were used and the line was pressurized to 65 PSI for 45 minutes in accordance with NC GS 143-139.3. Inspection of LPG 2417.1.

A handwritten signature in black ink, appearing to be "A. B.", is written over a horizontal line.

Signed by Licensed Contractor performing work