

June 6th, 2024

Triverse Builders
202 Coley Farm Rd
Fuquay Varina, NC 27526

Re: Status of Permit Application-SFD2401-0059

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines flagged every 50' and irons that are set by surveyor need to be visible. Need front right property corner irons uncovered and demonstrated. (\$25.00 Fee incurred)
- 2. House Box needs to be marked (25.00 Fee Incurred)
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs undergrowth cleared, do not disturb the soil
- 5. Driveway not shown on site plan
- 6. Backhoe Pits Required
- 7. **Other – New soil evaluation was taken and there is not enough room for initial septic system and repair area. Will need soil scientist layout.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh

Copy: Central Permitting