

Harnett County Department of Public Health

PERMIT # SFD 2401-0065

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 187 Golden Leaf Rd,

Name: (owner) Drees Homes company SUBDIVISION Tobacco Road LOT # 17

System Installer: Full Circle

Basement with plumbing: Garage Number of Bedrooms 5

Type of Water Supply: Community Public Well Distance from well _____ feet

System Type: 25% Reduction Type III(b) EZ Flow Types V and VI Systems expire in 5 years.


(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

~~*Needs Pump + Alarm
For Final~~

~~*Need to see if Manifold
was moved to meet 10' setback
(was 6' from property line at time of inspection)~~



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____
V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other Type III(b) EZ Flow Septic Tank: 1,200 gallons Pump Tank: 1,200 gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 1 of each ditch 390' feet ditches 3 feet ditches 24" inches

French Drain Required: _____ Linear feet

Authorized State Agent [Signature] Date 6-12-24