



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

11/6/2024

SUBJECT: SFD2401-0077
SINGLE FAMILY DWELLING

To: CUMBERLAND HOMES INC

Here are the results of all Inspections located at **25 PREACHER LN:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FINAL SFD STEMWALL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: T-POLE
Scheduled Date/Time: 4/25/2024
Completed Date/Time: 4/25/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/24/2024 8:29 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

No t pole

Inspection Type: FOOTING
Scheduled Date/Time: 4/25/2024
Completed Date/Time: 4/25/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/24/2024 8:29 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

Inspection Type: FOUNDATION
Scheduled Date/Time: 5/29/2024
Completed Date/Time: 5/29/2024
Inspector: Deen Taylor
Result: CANCELLED
Remarks: eTRAKiT Inspection Request
Notes: 5/28/2024 9:32 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroup@yahoo.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 6/4/2024
Completed Date/Time: 6/4/2024
Inspector: Daniel L Floyd
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/3/2024 10:36 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 6/13/2024
Completed Date/Time: 6/13/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/12/2024 1:21 PM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time: 6/13/2024
Completed Date/Time: 6/13/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/12/2024 12:44 PM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SLAB
Scheduled Date/Time: 6/19/2024
Completed Date/Time: 6/19/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/18/2024 12:28 PM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

Inspection Type: T-POLE
Scheduled Date/Time: 7/19/2024
Completed Date/Time: 7/19/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: 7/18/2024 10:23 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

need to secure the pole and wasn't able to locate ground rod

Inspection Type: T-POLE
Scheduled Date/Time: 7/25/2024
Completed Date/Time: 7/25/2024
Inspector: Scott Guy
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 7/24/2024 8:35 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

Address must be posted clearly legible from the street or roadway at all times. NCGS Temp power pole must be installed on the property.



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: T-POLE
Scheduled Date/Time: 7/30/2024
Completed Date/Time: 7/30/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 7/29/2024 10:47 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/31/2024
Completed Date/Time: 7/31/2024
Inspector: Deen Taylor
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 7/30/2024 9:06 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

No plumbing test gauge for supply lines

Inspection Type: INSULATION
Scheduled Date/Time: 8/6/2024
Completed Date/Time: 8/6/2024
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 8/5/2024 11:56 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 8/6/2024
Completed Date/Time: 8/6/2024
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 8/5/2024 11:56 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroupnc@gmail.com

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time: 8/21/2024
Completed Date/Time: 8/21/2024
Inspector: Reynold J Levocz
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 9/19/2024
Completed Date/Time: 9/19/2024
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 9/18/2024 9:29 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC
Site Address: 25 PREACHER LN
Phone: 9108924345
e-Mail: NorrisBuildingGroup@yahoo.com





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 10/15/2024
Completed Date/Time: 10/15/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/14/2024 11:13 AM CUMBERLAND HOMES INC

Contact Name: CUMBERLAND HOMES INC

Site Address: 25 PREACHER LN

Phone: 9108924345

e-Mail: NorrisBuildingGroup@yahoo.com