

Truss Placement Plan SCALE: NTS

___ = Indicates Left End of Truss (Reference Engineered Truss Drawing) Do NOT Erect Truss Backwards

LOAD CHART FOR JACK STUDS										
(BASED ON TABLES R502.5(1) & (b))										
NUMBER OF JACK STUDS REQUIRED @ EA END C HEADER/GIRDER										
END REACTION (UP TO)	REQ'D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (4) PLY HEADER			
1700	1		2550	1		3400	1			
3400	2		5100	2		6800	2			
5100	3		7650	3		10200	3			
6800	4		10200	4		13600	4			
8500	5		12750	5		17000	5			
10200	6		15300	6						
11900	7									
13600	8									
15300	9									

Truss

		_		
BUILDER	New Home Inc.	CITY / CO.	Lillington / Harnett	THIS These the bu sheets is resp the ov walls, regard or onli Bearin presci
JOB NAME	Lot 2 Heritage @ Neills Creek	ADDRESS	40 Eagle Crest Court	
PLAN	The Clayton - Low Country	MODEL	Floor	
SEAL DATE	Seal Date	DATE REV.	10/25/24	(derive found than 3 be ret
QUOTE#	B0224-1009	DRAWN BY	Johnnie Baggett	specif retaine
JOB#	J1024-5576	SALES REP.	Paul Hawkins	Sig

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
These trusses are designed as individual building components to be incorporated into ne building design at the specification of the building designer. See individual design heters for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for ne overall structure. The design of the truss support structure including headers, beams, ralls, and columns is the responsibility of the building designer. For general guidance grarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package ronline @ sbcindustry.com paring reactions less than or equal to 3000# are deemed to comply with the escriptive Code requirements. The contractor shall refer to the attached Tables ferived from the prescriptive Code requirements) to determine the minimum undation size and number of wood studs required to support reactions greater an 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those lecified in the attached Tables. A registered design professional shall be tained to design the support system for all reactions that exceed 15000#.

TRUSSES & BEAMS Johnnie Baggett

Johnnie Baggett

Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444

соттесн

ROOF & FLOOR