



ROOF & FLOOR TRUSSES & BEAMS

Reilly Road Industrial Park
Fayetteville, N.C. 28309
Phone: (910) 864-8787
Fax: (910) 864-4444

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature *Johnnie Baggett*

Johnnie Baggett

LOAD CHART FOR JACK STUDS


(BASED ON TABLES R502.5(1) & (b))
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER

END REACTION (UP TO)	REQ. STUDS FOR (1) 1" X 1" HEADER	END REACTION (UP TO)	REQ. STUDS FOR (1) 1" X 1" HEADER	END REACTION (UP TO)	REQ. STUDS FOR (1) 1" X 1" HEADER
1700	1	2550	1	3400	1
3400	2	5100	2	6800	2
5100	3	7650	3	10200	3
6800	4	10200	4	13600	4
8500	5	12750	5	17000	5
10200	6	15300	6		
11900	7				
13600	8				
15300	9				

CITY / CO.	Lillington / Harnett
ADDRESS	81 Eagle Crest Court
MODEL	Roof
DATE REV.	8/2/24
DRAWN BY	Johnnie Baggett
SALES REP.	Paul Hawkins

BUILDER	New Home Inc
JOB NAME	Lot 9 Heritage @ Neills Creek
PLAN	The Apex - Craftsman
SEAL DATE	Seal Date
QUOTE #	Quote #
JOB #	J0724-4218

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com



Dimension Notes
1. All exterior wall to wall dimensions are to face of sheathing unless noted otherwise
2. All interior wall dimensions are to face of stud unless noted otherwise
3. All exterior wall to truss dimensions are to face of stud unless noted otherwise

= 2828.86 sq.ft. Roof Area
= 71.96 ft. Ridge Line
= 30.82 ft. Hip Line
= 170.88 ft. Horiz. OH
= 160.02 ft. Raked OH
= 97 sheets Decking

All Walls Shown Are Considered Load Bearing

= Indicates Left End of Truss ▲ (Reference Engineered Truss Drawing) Do Not Erect Trusses Backwards

WALL SCHEDULE

1st Floor Walls	Yellow
2nd Floor Walls	Red
Non-Bearing Walls	White
Garage Walls Dropped	Cyan

Nail Information		Connector Information				
Truss	Header	Supported Member	Qty	Manuf	Product	Sym
16d/3-1/2"	16d/3-1/2"	NA	10	USP	HUS26	Blue
10d/3"	10d/3"	NA	20	USP	JUS24	Yellow
10d/3"	16d/3-1/2"	NA	1	USP	THD26-2	Green

Products

Net Qty	Plies	Product	Length	PlotID
2	2	1-3/4"x 14" LVL Kerto-S	8' 0"	2FB1
2	2	1-3/4"x 14" LVL Kerto-S	7' 0"	2FB5
2	2	1-3/4"x 14" LVL Kerto-S	4' 0"	2FB2
3	3	1-3/4"x 23-7/8" LVL Kerto-S	22' 0"	2FB3
2	2	1-3/4"x 23-7/8" LVL Kerto-S	16' 0"	2FB4
2	2	2x8 SPF No.2	4' 0"	BBO

Truss Placement Plan
SCALE: NTS

▲ = Indicates Left End of Truss (Reference Engineered Truss Drawing) Do NOT Erect Truss Backwards