

\*House footprint to be field staked by surveyor and system verified prior to any construction


\*\*Septic area must not be altered by construction activities.

\*\*\*No cuts of 2' or greater within 15' of septic area

\*\*\*\* Recommend protective barrier around septic field during construction.

3-Bedroom Septic Plan  
Lot #46 - Duncan's Crossing  
Harnett County  
Smith Douglas Homes

Lot could possibly be reworked for a 4-bedroom plan once temporary stormwater basin is removed.



46

44,687 SF  
(1.03 AC)

\*If plumbing is not sufficient a pump tank will be required to septic field.

System: Gravity to D-Box.  
Lines: Lines 1-4 (360')  
0.4 LTAR  
24" Max Trench Bottom  
Accepted Status System  
Repair: Gravity to D-Box  
Lines: Lines 5-8 (360')  
0.4 LTAR  
24" Trench Bottom  
Accepted Status System

DECOY SPREAD  
50' R/W (PUBLIC  
& UTILITY ACCESS)

GRAPHIC SCALE  
1" = 50'



Adams  
Soil Consulting  
919-414-6761  
Job #1146