

September 9, 2024

Mr. Blake Whitaker  
Great Southern Homes  
933 Old Knight Road  
Knightdale, North Carolina 27545

**Subject: Summary of Front Porch Evaluation  
Lot No. 8 – (159 Grand Griffon Way)  
Griffon Pointe Subdivision  
Lillington, North Carolina  
Permit Number: 2402-0041  
Project Number: 0040.F0001 (40414-02)**

Dear Mr. Whitaker:

On August 20, 2024, a representative of UES Professional Solutions 29, Inc. (**UES**) visited the subject site for the purpose of performing a front porch evaluation at the site referenced above. The following is a summary of our onsite observations and evaluations.

**UES** observed that the front porch slab areas were backfilled with washed stone (NCDOT #57 stone) prior to our site visit. **UES** probed the front porch slab areas using a ½" diameter steel T-handled probed rod and firm soils were encountered. The front porch bearing soils appeared suitable to support the proposed slab at the time of our inspection.

We appreciate the opportunity to assist you during this phase of the project. If you need further assistance or additional information please do not hesitate to contact us.

Sincerely,

**UES** Professional Solutions 29, Inc.

Jeff A. Taylor, P.E.  
Geotechnical Engineer

A handwritten signature in black ink, appearing to read "Adam D. Perry".

Adam D. Perry, E.I.  
Staff Professional