

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: Yes	Commercial Project: No
Code Enforcement Project No: -----	Permit No: 2402-0054
Project Name: Mckays Place 22	Owner: DR Horton
Project Address: 84 Finsbury Court	Suite No:
Date Inspected: 4-3-24	Contractor Name: RJ Concrete
Component Inspected: Footing - House - projection repair	

Responsible Licensed NC Architect or NC Engineer

Name:	Bryant Mueller		
Firm Name:	TM Engineering, Inc.		
Phone Numbers:	Office: 919-468-2545	Mobile:	
Email Address:	Bryantm@tmengineering.org		
Mailing Address:			

APPLICABLE CODE: 2018 NCRC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: *

Please see attached letter for site specific details and primary language regarding TME services.

*(subgrade form/letter may also be required)

Attestation/Signature:


By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the approved plans & specifications for the project. This inspection is in compliance with all of the requirements of the above referenced code. Attach any additional documents if needed.



Licensed Architect or Engineer

4/3/24

Date



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.


REPORT

TO: DR Horton

FROM: TM Engineering, Inc.

PROJECT: Mckays Place Lot 22

DATE: April 3, 2024



TME observed projection repair for four areas circled on plans. Contractor doveled into existing concrete footer with rebar every 6 inches. Foundation area extended to provide sufficient projection.

It should be noted that minor cracking commonly occurs in construction for various reasons including but not limited to, temperature fluctuations relative to expansion and contraction of materials, concrete shrinkage, changes in moisture content, improper construction, and normal settlement. No warranty is implied for such items by this letter. No performance guarantee shall be assumed. In all cases the contractor is solely responsible for the direction and quality of the work, adherence to the plans and specifications, and scheduling inspections. Only the client or it's designated representatives with written consent may use this document.

