

### Harnett County Central Permitting

420 McKinney Pkwy / PO Box 65 Lillington, NC 27546 - centralpermitting@harnett.org  
Ph.: 910-893-7525 - Fax: 910-893-2793 / www.harnett.org/permits  
Certification of Work Performed By Owner/Contractor  
(Individual Trade Application)

Owner (s) of Structure: Drees Homes Phone: \_\_\_\_\_  
Owner (s) Mailing Address: 9521 Six Forks Rd Ste 500 Raleigh

Land Owner Name (s): Drees Homes Phone: \_\_\_\_\_  
Construction or Site Address: 15 Gooding Stick Ct Angier  
PIN # \_\_\_\_\_ Parcel # \_\_\_\_\_

Job Cost (Required): 800.00 Description of Work to be done Bury 500 gal propane tank + line to stub out

Mechanical: New Unit With Ductwork \_\_\_ New Unit Without Ductwork \_\_\_ Gas Piping  Other \_\_\_  
Electrical\*: 200 Amp \_\_\_ <200 Amp \_\_\_ Service Change \_\_\_ Service Reconnect \_\_\_ Other \_\_\_  
\* For Progress Energy customers we need the premise number  
Plumbing: Water/Sewer Tap \_\_\_ Number of Baths \_\_\_ Water Heater \_\_\_

Specific Directions to Job from Lillington:  
\_\_\_\_\_  
\_\_\_\_\_

Subdivision: \_\_\_\_\_ Lot #: \_\_\_\_\_

I Hunter oil + Propane will provide the Mechanical labor on this structure.  
(Contractors Name) (Trade)

I am the building owner or my NC state license number is 22196, which entitles me to perform such work on the above structure legally. All work shall comply with the State Building Code and all other applicable State and local laws, ordinances and regulations.

Hunter oil + Propane  
Contractor's Company Name  
1003 S. Harker Blvd Sanford  
Address  
22196  
License #

919-725-5651  
Telephone  
richardhunteroil@gmail.com  
Email Address

Structure Owner / Contractor Signature: [Signature] Date: 7-10-24

By signing this application you affirm that you have obtained permission from the above listed license holder to purchase permits on their behalf. If doing the work as owner you understand that you cannot rent, lease or sell the listed property for 12 months after completion of the listed work

**\*Company name, address, & phone must match information on license**  
**Faxed or Mailed application could have an approximately 1-5 day process time**



ALTERNATE INSPECTIONS FOR LP GAS PIPINGSYSTEM FOR RESIDENTIAL  
STRUCTURES

July 10, 2024

To: Chatham County Inspections

From: Hunter Oil and Propane, Lic. # 22196

**RE: 15 Grading Stick Ct Angier NC**

Please be advised that we hereby certify that 80 feet of LP gas line was buried at or below the minimum depth required by North Carolina Code #404.12 Minimum Burial Depth. In addition we also hereby certify that approved materials were used and the line was pressurized to 65 PSI for 45 minutes in accordance with NC GS 143-139.3. Inspection of LPG 2417.1.

A handwritten signature in black ink, appearing to be "A. H. B.", is written over a horizontal line.

Signed by Licensed Contractor performing work