

**J.S. THOMPSON**  
**ENGINEERING, INC**

June 19, 2024

Josh Arnott  
Davidson Homes LLC  
4208 Six Forks Road  
Suite 100  
Raleigh, NC 27609

Dear Mr. Arnott:

The plan was reviewed for lot #24 Tobacco Road subdivision in Angier, North Carolina to address the beam in the second floor system noted by the inspector.

The (2) 1 3/4" x 14" LVL beam adjacent to the stairs with several holes drilled at the bottom edge for wires will provide the required support for all applied loads. No modification is required.

Please call me if you have any questions.

Sincerely,

J.S. Thompson Engineering, Inc.  
N.C. License No. C-1733

Matthew G. Strother, P.E.

