

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.



1403 NC Highway 50 South  
Benson, North Carolina 27504  
919.894.7765

Email: [general@enochengineers.com](mailto:general@enochengineers.com)

[www.enochengineers.com](http://www.enochengineers.com)

### MATERIALS & TEST DIVISION

#### FIELD REPORT

#### PROJECT

CLIENT:	FREEDOM CONSTRUCTO	DATE:	9.18.24
PROJECT:	RESI STEM WALL FILL	CONTRACTOR:	R. HAIRE
ADDRESS:	598 PRAIRE LN	TECHNICIAN:	BLH
LOT #:	LILLINGTON NC		

#### TEST SUMMARY

PERFORMED NDT ON RESI STEM WALL SOIL FILL MATERIAL AT SITE NOTED ABOVE USING A TARGET DENSITY OF 115 PCF.  
SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

#### TESTING RESULTS

SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	96.08	110.5	121.4	9.9

#### RETURN VISIT REQUIRED

YES   
NO

TECHNICIAN:  


Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.