



**TO:** Jonathan Humbert  
**PROJECT #:** 23-1872-A  
**PAGE:** 1 of 1  
**DATE:** January 28, 2025  
**LOCATION:** NC 55 East, Erwin NC  
**PLAN REF:** Humbert Residence by K&A Home Design  
Project# 23-1872-A

**THE FOLLOWING CHANGE(S) OR PROPOSED CHANGE(S) LISTED BELOW ARE DEVIATIONS OR CLARIFICATIONS FOR THE ABOVE REFERENCED PLANS:**

Garage Wall Studs: Per information provided by the builder the Garage walls are 10'-10" tall which exceeds the code limit of 10'. The Garage walls are framed with 2 x 4 @ 16" OC.

**Response:** The Garage walls described above are acceptable provided that an additional stud is added to every third stud.

In closing, I trust this letter fulfills your requirements at this time. Should you have any further questions, please do not hesitate to call.

Sincerely,  
James Herman, P.E.

Southern Engineers, P.A.

