Jason E Godwin, P.L.S.



Email: general@enochengineers.com

www.enochengineers.com

## MATERIALS & TEST DIVISION

## FIELD REPORT

CLIENT:	CARROLL CONST	DATE:	9.4.24
PROJECT:	SHILOH S/D	CONTRACTOR:	D. PEEBLES
ADDRESS:	206 COHARIE DR	TECHNICIAN:	BLH ·
LOT#:	81		

## **TEST SUMMARY**

PERFORMED NDT ON GARAGE SOIL FILL MATERIAL AT SITE NOTED ABOVE USING A TARGET DENSITY OF 108 PCF.
SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

	TESTING RESULTS				
SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	96.64	105.4	109.7	4.0

YES TECHNICIAN:

NO Disclaimer GODWIN, In GO

Soils & Material inspections, testing results and on-site determinations contained in this report become world offer 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.