

Joe E Godwin Sr., P.E., P.L.S.

Jason E Godwin, P.L.S.

**E**NOCH  
ENGINEERS, P.A.  
1403 NC Highway 50 South  
Benson, North Carolina 27504  
919.894.7765

Email: [general@enochengineers.com](mailto:general@enochengineers.com)

[www.enochengineers.com](http://www.enochengineers.com)

## MATERIALS & TEST DIVISION

### FIELD REPORT

#### PROJECT

CLIENT: CARROLL CONST

DATE: 9.4.24

PROJECT: SHILOH S/D

CONTRACTOR: D. PEEBLES

ADDRESS: 166 COHARIE DR

TECHNICIAN: BLH

LOT #: 83

#### TEST SUMMARY

PERFORMED NDT ON GARAGE SOIL FILL MATERIAL AT SITE NOTED ABOVE  
USING A TARGET DENSITY OF 108 PCF.  
SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

#### TESTING RESULTS

SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	99.27	107.2	109.9	2.5

#### RETURN VISIT REQUIRED

YES   
NO

TECHNICIAN:

*BLH*

*Joe E Godwin Sr.*  
 NORTH CAROLINA PROFESSIONAL SEAL  
 00951  
 ENGINEER  
 GODWIN, SR.  
 9/4/24

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.