



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/1/2025

SUBJECT: **SFD2404-0008**
SINGLE FAMILY DWELLING

To: Jeremy STRickland

Here are the results of all Inspections located at **233 JENKINS ST:**

Inspection Type: FINAL SFD MONO**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 4/2/2024
Completed Date/Time: 4/2/2024
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 233 JENKINS ST DUNN 28334.



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time: 4/25/2024
Completed Date/Time: 4/25/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time: 4/26/2024
Completed Date/Time: 4/26/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 7/18/2025
Completed Date/Time: 7/18/2025
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 7/18/2025
Completed Date/Time: 7/18/2025
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time: 8/13/2025
Completed Date/Time: 8/13/2025
Inspector: CP Bucket
Result: APPROVED
Remarks: NEEDED
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: T-POLE
Scheduled Date/Time: 8/14/2025
Completed Date/Time: 8/14/2025
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/14/2025
Completed Date/Time: 8/14/2025
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: LOCK BOX 8080

1. Shim truss bearing points on outer wall
2. Rough in toilet flange to correct depth
3. Fire block top of packed out wall in living room
4. Need Uplift connection on gables where required.

Inspection Type: INSULATION
Scheduled Date/Time: 8/15/2025
Completed Date/Time: 8/15/2025
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/15/2025
Completed Date/Time: 8/15/2025
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 10/1/2025
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes: LOCK BOX 8080