

	HUS26	USP	5	NA	16d/3-1/2"	16d/3-1/2"
	JUS26	USP	6	NA	10d/3"	10d/3"

Truss Placement Plan SCALE: NTS

= Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards

LOAD CHART FOR JACK STUDS								
(BASED ON TABLES R502.5(1) & (b))								
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER								
END REACTION (UP TO)	REQ'D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (4) PLY HEADER	
1700	1		2550	1		3400	1	
3400	2		5100	2		6800	2	
5100	3		7650	3		10200	3	
6800	4		10200	4		13600	4	
8500	5		12750	5		17000	5	
10200	6		15300	6				
11900	7							
13600	8							
15300	9							

BUILDER	A & G Residential	CITY / CO. Lilington / Harnett	Lilington / Harnett	THIS IS A TR These trusses a the building desi sheets for each t is responsible fo the overall struct walls, and colum regarding bracin or online @ sbci Bearing reactio prescriptive Co
JOB NAME	Lot 18 Jones Creek	ADDRESS	110 Mossy Bridge Ct.	
PLAN	Rose B Roof	MODEL R	Roof	
SEAL DATE	1/15/2025	DATE REV.	02/17/25	(derived from foundation size than 3000# but be retained to
QUOTE#		DRAWN BY	Marshall Naylor	specified in the retained to des
JOB#	J1024-5560	SALES REP.	Marshall Naylor	Signature_

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Marshall Naylor

Marshall Naylor



Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444