



Permit Inspections

Harnett County

Permit Number: SFD2404-0044

Description: 50x45 sfd 4 beds 3.5 baths

Applied: 4/9/2024

Approved: 6/10/2024

Site Address: 122 WHIMBREL CT

Issued: 6/28/2024

Finalized: 11/13/2024

City, State Zip Code: LILLINGTON, NC 27546

Status: FINALED

Applicant: DRB Group North Carolina, LLC

Parent Permit:

Owner: DRB GROUP NORTH CAROLINA LLC

Parent Project:

Contractor: DRB Group North Carolina, LLC

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			GAS PIPING	Deen Taylor		

Notes:

	7/3/2024	7/3/2024	T-POLE	Deen Taylor	APPROVED	eTRAKiT Inspection Request
--	----------	----------	--------	-------------	----------	----------------------------

Notes:

7/2/2024 12:38 PM DC Carter
Dean has an open floor at 127 so maybe he can pick this up Happy July 4,th yall
Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com

	7/10/2024	7/10/2024	ADDRESS	GIS Bucket	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	---------	------------	----------	----------------------------

Notes:

7/9/2024 12:32 PM DC Carter

Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com

122 WHIMBREL CT LILLINGTON 27546.

	7/10/2024	7/10/2024	FOOTING	Deen Taylor	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	---------	-------------	----------	----------------------------

Notes:

7/9/2024 12:31 PM DC Carter

Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com



Permit Inspections

Harnett County

	7/23/2024	7/23/2024	FOUNDATION	Deen Taylor	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>7/22/2024 11:06 AM DC Carter damp proof has been completed Thanks Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p>						
	8/1/2024	8/1/2024	OPEN FLOOR	Deen Taylor	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>7/31/2024 9:26 AM DC Carter Thank You Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p>						
	8/27/2024	8/27/2024	WATER CONNECTION	Scott Guy	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>8/26/2024 1:47 PM DC Carter Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p>						
	8/28/2024	8/28/2024	ROUGH IN	Daniel L Floyd	DISAPPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>8/25/2024 7:34 AM DC Carter Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p> <p>Inspector DT changed the inspection assignment from DT to DLF</p> <p>1. H clip ripped off of a roof truss in the rear of the 3rd car garage 2. Missing nails in all of the roof truss hangers in the garage 3. Missing 2(2x4) stud column at hold down in the room behind the garage 4. Need another king stud on each side of the rear door5. Missing 2x8 headers over windows to the right of the back door 6. Need power ran to the low voltage panel 7. Stair landing needs hangers as called for on the plans or an engineer letter and missing 2(2x8) flush across the landing with 2(2x4) bm pocket 8. Missing nails in the hangers over the half bath 9. All nails in the hangers going into the girder truss need to be 10d 3 inch nails 10. Water supply test low11. Need air barrier and insulation in chase by the stairs Ok to insulate</p>						



Permit Inspections

Harnett County

	8/30/2024	8/30/2024	ROUGH IN REINSPECT	Scott Guy	DISAPPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>8/28/2024 3:57 PM DC Carter</p> <p>Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p> <p>Insulation contractors working</p>						
	9/3/2024	9/3/2024	ROUGH IN REINSPECT	Scott Guy	FAIL W/ PENALTY	eTRAKiT Inspection Request
<p>Notes:</p> <p>8/30/2024 2:00 PM DC Carter</p> <p>Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p> <p>Iteams from previous not corrected #4 framer removed switch box to make the repair and did not install it back. #7 # 10 #11</p>						
	9/5/2024	9/5/2024	ROUGH IN REINSPECT	Scott Guy	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>9/4/2024 9:28 AM DC Carter</p> <p>Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p>						
	9/20/2024	9/20/2024	SEWER CONNECTION	Scott Guy	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>9/19/2024 11:53 AM DC Carter</p> <p>Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p>						
	10/7/2024	10/7/2024	TEMP POWER CERTIFICATION	Deen Taylor	DISAPPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>8/28/2024 5:37 PM DC Carter</p> <p>Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com</p>						



Permit Inspections

Harnett County

10/1/2024 7:55 PM DC Carter

Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com

House locked. Cover for panel in garage missing

	10/9/2024	10/9/2024	TEMP POWER CERTIFICATION	Deen Taylor	DISAPPROVED	eTRAKiT Inspection Request
--	-----------	-----------	-----------------------------	-------------	-------------	----------------------------

Notes:

10/7/2024 8:12 PM DC Carter

Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com

House locked

	10/11/2024	10/11/2024	TEMP POWER CERTIFICATION	Deen Taylor	APPROVED	
--	------------	------------	-----------------------------	-------------	----------	--

Notes:

0	8/30/2024	8/30/2024	INSULATION	Scott Guy	DISAPPROVED	eTRAKiT Inspection Request
---	-----------	-----------	------------	-----------	-------------	----------------------------

Notes:

8/27/2024 10:31 PM DC Carter

Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com

8/27/2024 10:35 PM DC Carter

Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com

Insulation contractors working

0	9/5/2024	9/5/2024	INSULATION REINSPECTION	Scott Guy	APPROVED	eTRAKiT Inspection Request
---	----------	----------	----------------------------	-----------	----------	----------------------------

Notes:

9/4/2024 9:28 AM DC Carter

Contact Name: DC Carter
Site Address: 122 WHIMBREL CT
Phone: 9198962168
e-Mail: dcarter@drbgroup.com



Permit Inspections Harnett County

20	8/28/2024	8/28/2024	FOUNDATION SURVEY	Donna Johnson	APPROVED	NEEDED
Notes:						
30	9/3/2024	9/3/2024	INSULATION REINSPECTION	Scott Guy	DISAPPROVED	eTRAKiT Inspection Request
Notes: 8/30/2024 1:59 PM DC Carter Contact Name: DC Carter Site Address: 122 WHIMBREL CT Phone: 9198962168 e-Mail: dcarter@drbgroup.com All trade inspections failed						
30	10/25/2024	10/25/2024	ENVIR OPERATIONS PERMIT	Reynold J Levocz	APPROVED	
Notes:						
50	11/13/2024	11/13/2024	FINAL SFD CRAWL**	Deen Taylor	APPROVED	
Notes:						