

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

September 5th, 2024

Juan Sandoval
1259 Lafayette Rd
Fuquay Varina, NC 27526

Re: Status of Permit Application-SFD2404-0047

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

 1. Use pink flags to mark back property lines, survey irons to be located and demonstrated. (25.00 Fee Incurred)

 2. House Box needs to be corrected and marked/demonstrated. (25.00 Fee Incurred)

 3. Directions not clear to property (*\$25.00 fee incurred*)

 4. Property needs undergrowth cleared, vegetation must be cleared (brushes, limbs, briars) in area behind house box to determine the change in soil and available septic room for the initial and repair area.

 5. Driveway not shown on site plan

 6. Backhoe Pits Required-

X 7. Other –Move the House box farther back behind the white flags Environmental Health left onsite. -Make the Driveway hug either left or right side of the property line. (Cannot be middle due to having to use front yard for septic area.

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy: Central Permitting