



A A TAKLA ENGINEERING, PLLC

Consulting. Design. Efficiency.

Atef A. Takla, PE | 919-358-1758 | ateftakla@taklaengr.com

NC Firm License No. P-1446
418 Vivaldi Dr. Durham, NC 27712



Project: LOT 47 COTTON FARM
Location: FURFAY - VARINA, NC
Date: 7/9/24
Company: _____
Care Of: Edgar.
Per# SFD 2404-0048

7/9/24

AS REQUESTED, A. TAKLA OBSERVED THE COMPLETED REPAIRS FOR FOOTINGS LACK TWO (2) INCHES PROJECTION AND FOUND REPAIRS AS COMPLETED PER RECOMMENDATION AND ARE ACCEPTABLE.

O.K TO POUR CONCRETE.

Limitations of Inspection: Services provided are in accordance with the standard of practice for structural engineering and within the limits imposed by scope, schedule and budget. The determinations contained in this report are based on conditions observed at the time of the evaluation. No guarantees or warranties, expressed or implied, under this Agreement or otherwise, shall be construed in connection with services provided. Sequencing, shoring, means and methods of construction are considered beyond the scope of this report.