



Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

April 23rd, 2024

ph: 910-893-7550

fax: 910-893-9429

Triple A Homes  
Po Box 1117  
Holly Springs, NC 27540

**Re: Status of Permit Application-SFD2404-0048**

**To whom it may concern,**

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. House Box needs to be marked to match site plan (\$25.00 Fee Incurred)
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs undergrowth cleared, do not disturb the soil
- 5. Driveway not shown on site plan
- 6. Backhoe Pits Required
- 7. **Other – Due to the lots limited space, it will be required to have adequate clearing to determine if there is space to fit an initial and repair area for the systems. (Clearing Areas) Back of house box to the existing drainage ditch, there also may be a small area in the front of the house.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Reynold Levocz R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

RL/kh

Copy: Central Permitting