

Trenco
818 Soundside Rd
Edenton, NC 27932

Re: J0424-2035
Lot 165 Duncans Creek

The truss drawing(s) referenced below have been prepared by Truss Engineering Co. under my direct supervision based on the parameters provided by Comtech, Inc - Fayetteville.

Pages or sheets covered by this seal: I64784324 thru I64784346

My license renewal date for the state of North Carolina is December 31, 2024.

North Carolina COA: C-0844



April 9, 2024



Gilbert, Eric

IMPORTANT NOTE: The seal on these truss component designs is a certification that the engineer named is licensed in the jurisdiction(s) identified and that the designs comply with ANSI/TPI 1. These designs are based upon parameters shown (e.g., loads, supports, dimensions, shapes and design codes), which were given to MiTek or TRENCO. Any project specific information included is for MiTek's or TRENCO's customers file reference purpose only, and was not taken into account in the preparation of these designs. MiTek or TRENCO has not independently verified the applicability of the design parameters or the designs for any particular building. Before use, the building designer should verify applicability of design parameters and properly incorporate these designs into the overall building design per ANSI/TPI 1, Chapter 2.

Job J0424-2035	Truss F01	Truss Type FLOOR	Qty 5	Ply 1	Lot 165 Duncans Creek 164784324 Job Reference (optional)
-------------------	--------------	---------------------	----------	----------	--

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:13 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f




LOADING (psf)	SPACING-	CSI.	DEFL.	PLATES	GRIP
TCLL 40.0	2-0-0	TC 0.59	in (loc) l/defl L/d	MT20	244/190
TCDL 10.0	Plate Grip DOL 1.00	BC 0.62	Vert(LL) -0.14 23-24 >999 480		
BCLL 0.0	Lumber DOL 1.00	WB 0.37	Vert(CT) -0.19 23-24 >859 360		
BCDL 5.0	Rep Stress Incr YES	Matrix-S	Horz(CT) 0.03 15 n/a n/a		
	Code IRC2015/TP12014			Weight: 111 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 25=0-3-8, 15=0-3-8, 19=0-3-8
Max Grav 25=686(LC 10), 15=405(LC 4), 19=1439(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-1506/0, 3-4=-2025/0, 4-5=-2025/0, 5-6=-2025/0, 6-8=-1060/2, 8-9=0/1109, 9-10=0/1108, 10-11=-407/304, 11-12=-714/61, 12-13=-714/61
BOT CHORD 24-25=0/1057, 23-24=0/1898, 22-23=0/2025, 21-22=0/1621, 19-21=-201/491, 18-19=-505/86, 17-18=-61/714, 16-17=-61/714, 15-16=0/450
WEBS 2-25=-1219/0, 2-24=0/584, 3-24=-510/0, 3-23=-86/307, 8-19=-1462/0, 8-21=0/781, 6-21=-784/0, 6-22=0/723, 5-22=-333/0, 13-15=-561/0, 13-16=-101/336, 10-19=-886/0, 10-18=0/544, 11-18=-584/0

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 5) CAUTION, Do not erect truss backwards.



WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPH Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)



Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek	164784325
J0424-2035	F02	FLOOR	2	1	Job Reference (optional)	

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:14 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f





Plate Offsets (X,Y)--	[13:0-1-8,Edge], [14:0-1-8,Edge], [25:0-3-0,Edge]				
LOADING (psf)	SPACING- 1-7-3	CSI.	DEFL. in (loc) l/defl L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL 1.00	TC 0.79	Vert(LL) -0.22 23-24 >973 480	MT20	244/190
TCDL 10.0	Lumber DOL 1.00	BC 0.76	Vert(CT) -0.30 23-24 >709 360		
BCLL 0.0	Rep Stress Incr YES	WB 0.50	Horz(CT) 0.04 19 n/a n/a		
BCDL 5.0	Code IRC2015/TPI2014	Matrix-S			
				Weight: 118 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 28=0-3-8, 16=0-3-8, 19=0-3-8
 Max Uplift 16=249(LC 3)
 Max Grav 28=719(LC 10), 16=101(LC 4), 19=1357(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
 TOP CHORD 2-3=-1630/0, 3-4=-2766/0, 4-5=-2766/0, 5-6=-2766/0, 6-8=-2581/0, 8-9=-1826/0, 9-10=-1826/0, 10-11=-492/0, 11-12=0/1325, 12-13=0/1324, 13-14=-15/569
 BOT CHORD 27-28=0/1085, 25-27=0/2240, 24-25=0/2768, 23-24=0/2786, 22-23=0/2322, 20-22=0/1251, 19-20=-387/0, 18-19=-569/15, 17-18=-569/15, 16-17=-569/15
 WEBS 2-28=-1267/0, 2-27=0/710, 3-27=-792/0, 3-25=0/792, 11-19=-1283/0, 11-20=0/1046, 10-20=-997/0, 10-22=0/742, 8-22=-640/0, 8-23=0/344, 6-23=-276/0, 6-24=-180/296, 14-16=-14/710, 13-19=-1050/0, 13-18=0/255

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 16=249.
 - 5) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 6) CAUTION, Do not erect truss backwards.



Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek	164784326
J0424-2035	F03	FLOOR	4	1	Job Reference (optional)	

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:14 2024 Page 1
 ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f





Plate Offsets (X, Y)--	[6:0-3-0,Edge], [7:0-3-0,0-0-0], [18:0-3-0,Edge], [19:0-3-0,Edge]
------------------------	---

LOADING (psf)	SPACING-	1-7-3	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL	1.00	TC 0.21	Vert(LL)	-0.18 18-19	>999	480	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.52	Vert(CT)	-0.25 18-19	>870	360		
BCLL 0.0	Rep Stress Incr	YES	WB 0.42	Horz(CT)	0.04 14	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-S						


Weight: 116 lb FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	


REACTIONS. (size) 24=0-3-8, 14=0-3-8
 Max Grav 24=791(LC 1), 14=786(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
 TOP CHORD 2-3=-1627/0, 3-4=-2887/0, 4-5=-2892/0, 5-6=-3790/0, 6-7=-3790/0, 7-8=-3790/0,
 8-10=-2916/0, 10-11=-2912/0, 11-12=-1660/0
 BOT CHORD 23-24=0/942, 21-23=0/2336, 19-21=0/3487, 18-19=0/3790, 17-18=0/3528, 15-17=0/2362,
 14-15=0/982
 WEBS 2-24=-1203/0, 2-23=0/891, 3-23=-923/0, 3-21=0/687, 5-21=-732/0, 5-19=0/638,
 6-19=-268/0, 12-14=-1230/0, 12-15=0/883, 11-15=-914/0, 11-17=0/686, 8-17=-750/0,
 8-18=-30/607

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) Plates checked for a plus or minus 1 degree rotation about its center.
 - 3) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.



April 9, 2024

<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	<p>ENGINEERING BY</p>  <p>A MiTek Affiliate</p> <p>818 Soundside Road Edenton, NC 27932</p>
--	---

Job J0424-2035	Truss F04	Truss Type Floor	Qty 3	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	I64784327
-------------------	--------------	---------------------	----------	----------	---	-----------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:15 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f






Plate Offsets (X,Y)--	[18:0-3-0,Edge], [19:0-3-0,Edge]				
LOADING (psf)	SPACING- 2-0-0	CSI.	DEFL. in (loc) l/defl L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL 1.00	TC 0.46	Vert(LL) -0.25 18-19 >839 480	MT20	244/190
TCDL 10.0	Lumber DOL 1.00	BC 0.63	Vert(CT) -0.35 18-19 >610 360		
BCLL 0.0	Rep Stress Incr YES	WB 0.52	Horz(CT) 0.05 14 n/a n/a		
BCDL 5.0	Code IRC2015/TPI2014	Matrix-S			
				Weight: 104 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 5-11-12 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 24=0-3-8, 14=Mechanical
Max Grav 24=973(LC 1), 14=973(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
 TOP CHORD 2-3=-1996/0, 3-4=-3526/0, 4-5=-3526/0, 5-6=-4319/0, 6-7=-4319/0, 7-8=-4319/0, 8-10=-3552/0, 10-11=-3552/0, 11-12=-2037/0
 BOT CHORD 23-24=0/1159, 21-23=0/2860, 19-21=0/4013, 18-19=0/4319, 17-18=0/4027, 15-17=0/2894, 14-15=0/1208
 WEBS 2-24=-1480/0, 2-23=0/1090, 3-23=-1124/0, 3-21=0/832, 5-21=-607/0, 5-19=0/662, 12-14=-1515/0, 12-15=0/1080, 11-15=-1115/0, 11-17=0/822, 8-17=-594/0, 8-18=-5/650

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Refer to girder(s) for truss to truss connections.
 - 5) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 6) CAUTION, Do not erect truss backwards.



April 9, 2024

<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	 818 Soundside Road Edenton, NC 27932
--	---

Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek
J0424-2035	F05	FLOOR	1	1	I64784328
					Job Reference (optional)

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:15 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



Scale = 1:29.6




Plate Offsets (X,Y)--	[1:Edge,0-1-8]					PLATES	GRIP	
LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	
TCLL 40.0	Plate Grip DOL 1.00	TC 0.39	Vert(LL) -0.24	19-20	>869	480		
TCDL 10.0	Lumber DOL 1.00	BC 0.62	Vert(CT) -0.33	19-20	>632	360		
BCLL 0.0	Rep Stress Incr YES	WB 0.50	Horz(CT) 0.05	14	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014	Matrix-S						
							Weight: 104 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 24=Mechanical, 14=Mechanical
Max Grav 24=960(LC 1), 14=960(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

TOP CHORD 2-3=-2006/0, 3-4=-3486/0, 4-6=-3486/0, 6-7=-4216/0, 7-8=-4216/0, 8-9=-4216/0, 9-10=-3486/0, 10-11=-3486/0, 11-12=-2006/0

BOT CHORD 23-24=0/1192, 21-23=0/2846, 20-21=0/3948, 19-20=0/4216, 17-19=0/3948, 15-17=0/2846, 14-15=0/1192

WEBS 2-24=-1495/0, 2-23=0/1060, 3-23=-1093/0, 3-21=0/798, 12-14=-1495/0, 12-15=0/1060, 11-15=-1093/0, 11-17=0/798, 9-17=-576/0, 9-19=-26/606, 6-21=-576/0, 6-20=-26/606

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Refer to girder(s) for truss to truss connections.
 - 5) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.




April 9, 2024

<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	<p>ENGINEERING BY</p> <p>TRENCO</p> <p>A MiTek Affiliate</p> <p>818 Soundside Road Edenton, NC 27932</p>
--	---


Job J0424-2035	Truss F06	Truss Type Floor	Qty 1	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	I64784329
-------------------	--------------	---------------------	----------	----------	---	-----------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:16 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



Scale = 1:31.0



	17-2-12	18-6-0
	17-2-12	1-3-4
Plate Offsets (X,Y)--	[1:Edge,0-1-8], [7:0-1-8,Edge], [18:0-3-0,Edge]	

LOADING (psf)	SPACING-	CSI.	DEFL.	PLATES	GRIP
TCLL 40.0	2-0-0	TC 0.60	in (loc) l/defl L/d	MT20	244/190
TCDL 10.0	Plate Grip DOL 1.00	BC 0.67	Vert(LL) -0.23 19 >894 480		
BCLL 0.0	Lumber DOL 1.00	WB 0.50	Vert(CT) -0.31 19 >661 360		
BCDL 5.0	Rep Stress Incr NO	Matrix-S	Horz(CT) 0.05 14 n/a n/a		
	Code IRC2015/TPI2014			Weight: 107 lb	FT = 20%F, 11%E


LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing, Except: 6-0-0 oc bracing: 14-15.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 24=Mechanical, 14=0-4-15
Max Grav 24=925(LC 3), 14=1820(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-1917/0, 3-4=-3316/0, 4-5=-3316/0, 5-6=-3884/0, 6-7=-3884/0, 7-8=-3280/0, 8-10=-2004/96, 10-11=0/829, 11-12=0/827
BOT CHORD 23-24=0/1145, 21-23=0/2719, 19-21=0/3698, 18-19=0/3884, 17-18=0/3884, 15-17=0/2778, 14-15=-374/1246
WEBS 10-14=-1740/0, 10-15=0/1045, 8-15=-1054/0, 8-17=0/700, 7-17=-1060/0, 7-18=-88/419, 2-24=-1437/0, 2-23=0/1005, 3-23=-1044/0, 3-21=0/745, 5-21=-499/0, 5-19=-178/536, 12-14=-1107/0

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Refer to girder(s) for truss to truss connections.
 - 5) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 6) CAUTION, Do not erect truss backwards.

LOAD CASE(S) Standard
1) Dead + Floor Live (balanced): Lumber Increase=1.00, Plate Increase=1.00
Uniform Loads (plf)
Vert: 13-24=-10, 1-12=-100
Concentrated Loads (lb)
Vert: 12=-700




April 9, 2024

<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	<p>ENGINEERING BY</p> <p>A MiTek Affiliate</p> <p>818 Soundside Road Edenton, NC 27932</p>
--	--

Job J0424-2035	Truss F07	Truss Type Floor	Qty 5	Ply 1	Lot 165 Duncans Creek I64784330
-------------------	--------------	---------------------	----------	----------	------------------------------------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:16 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



Scale = 1:31.4




Plate Offsets (X, Y)--	[1:Edge,0-1-8], [14:Edge,0-1-8], [19:0-3-0,Edge]
------------------------	--

LOADING (psf)	SPACING- 2-0-0	CSI.	DEFL. in (loc) l/defl L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL 1.00	TC 0.75	Vert(LL) -0.20 20-21 >943 480	MT20	244/190
TCDL 10.0	Lumber DOL 1.00	BC 0.75	Vert(CT) -0.27 20-21 >701 360		
BCLL 0.0	Rep Stress Incr NO	WB 0.58	Horz(CT) 0.03 15 n/a n/a		
BCDL 5.0	Code IRC2015/TP12014	Matrix-S			
				Weight: 109 lb	FT = 20%F, 11%E


LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 24=Mechanical, 15=0-3-8
Max Grav 24=839(LC 3), 15=1958(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 13-14=-748/0, 2-3=-1701/0, 3-4=-2894/0, 4-6=-2894/0, 6-7=-3082/212, 7-8=-3082/212, 8-9=-3082/212, 9-10=-1633/1019, 10-11=0/1845, 11-12=0/1844
BOT CHORD 23-24=0/1032, 21-23=0/2406, 20-21=0/3105, 19-20=-212/3082, 17-19=-630/2434, 15-17=-1340/898, 14-15=-844/0
WEBS 2-24=-1294/0, 2-23=0/871, 3-23=-918/0, 3-21=-11/609, 6-21=-314/203, 6-20=-516/326, 10-15=-1727/0, 10-17=0/1038, 9-17=-1201/0, 9-19=0/1209, 8-19=-323/0, 12-14=0/1127, 12-15=-1329/0

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) Plates checked for a plus or minus 1 degree rotation about its center.
 - 3) Refer to girder(s) for truss to truss connections.
 - 4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 5) CAUTION, Do not erect truss backwards.



LOAD CASE(S) Standard
1) Dead + Floor Live (balanced): Lumber Increase=1.00, Plate Increase=1.00
Uniform Loads (plf)
Vert: 14-24=-10, 1-13=-100
Concentrated Loads (lb)
Vert: 13=-700



Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek	I64784331
J0424-2035	F08	Floor	1	1	Job Reference (optional)	

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:17 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL	1.00	TC 0.69	Vert(LL)	-0.35	44	>728	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.72	Vert(CT)	-0.47	44	>534		
BCLL 0.0	Rep Stress Incr	YES	WB 0.71	Horz(CT)	0.06	37	n/a		
BCDL 5.0	Code IRC2015/TP12014		Matrix-S						
								Weight: 221 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat) *Except* 11-19: 2x4 SP 2400F 2.0E(flat)	TOP CHORD Structural wood sheathing directly applied or 5-8-9 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. All bearings 0-3-8.
(lb) - Max Grav All reactions 250 lb or less at joint(s) except 49=1029(LC 3), 37=1749(LC 3), 28=573(LC 4), 33=1169(LC 4)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-2484/0, 3-4=-4050/0, 4-5=-4050/0, 5-7=-4909/0, 7-8=-5090/0, 8-10=-4343/0, 10-12=-2926/0, 12-13=-2926/0, 13-14=-803/0, 14-15=0/2643, 15-16=0/2643, 16-17=0/2152, 17-18=0/2152, 18-20=0/1999, 20-21=0/1999, 21-22=-384/908, 22-23=-1389/254, 23-24=-1389/254, 24-25=-1389/254, 25-26=-1074/0
BOT CHORD 48-49=0/1633, 46-48=0/3363, 45-46=0/4564, 44-45=0/5090, 43-44=0/5090, 42-43=0/5090, 40-42=0/3695, 38-40=0/1939, 37-38=-637/0, 36-37=-2152/0, 35-36=-2152/0, 33-35=-1885/0, 32-33=-1181/0, 31-32=-611/965, 30-31=-254/1389, 29-30=-30/1386, 28-29=0/700
WEBS 2-49=-1885/0, 2-48=0/1108, 3-48=-1143/0, 3-46=0/858, 5-46=-640/0, 5-45=0/515, 7-45=-576/242, 7-44=-318/118, 14-37=-2373/0, 14-38=0/1498, 13-38=-1498/0, 13-40=0/1249, 10-40=-979/0, 10-42=0/832, 8-42=-1124/0, 8-43=-104/330, 16-37=-986/0, 18-33=-500/116, 18-35=-341/271, 26-28=-876/0, 26-29=-1/487, 25-29=-407/95, 25-30=-351/3, 21-33=-1284/0, 21-32=0/845, 22-32=-891/0, 22-31=0/859, 23-31=-373/0

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 5) CAUTION, Do not erect truss backwards.





April 9, 2024

<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	<p>ENGINEERING BY</p> <p>TRENCO</p> <p>A MITEK AFFILIATE</p> <p>818 Soundside Road Edenton, NC 27932</p>
--	---

Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek	I64784332
J0424-2035	F09	Floor	1	1	Job Reference (optional)	

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:19 2024 Page 1
ID:6XJu5EDhIOLdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



LOADING (psf)	SPACING-	1-7-3	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL	1.00	TC 0.82	Vert(LL)	-0.27	44	>922	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.56	Vert(CT)	-0.37	44	>675		
BCLL 0.0	Rep Stress Incr	YES	WB 0.57	Horz(CT)	0.05	37	n/a		
BCDL 5.0	Code IRC2015/TP12014		Matrix-S						
								Weight: 224 lb	FT = 20%F, 11%E


LUMBER-
TOP CHORD 2x4 SP No.1(flat)
BOT CHORD 2x4 SP No.1(flat)
WEBS 2x4 SP No.3(flat)

BRACING-
TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.

REACTIONS. All bearings 0-3-8 except (jt=length) 33=0-5-8.
(lb) - Max Grav All reactions 250 lb or less at joint(s) except 49=827(LC 3), 37=1389(LC 3), 33=931(LC 4), 28=470(LC 4)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-2002/0, 3-4=-3283/0, 4-5=-3283/0, 5-7=-3970/0, 7-8=-4140/0, 8-10=-3547/0, 10-11=-2413/0, 11-13=-2413/0, 13-14=-721/0, 14-15=0/2013, 15-16=0/2013, 16-17=0/1634, 17-18=0/1634, 18-19=0/1524, 19-21=0/1524, 21-22=-351/655, 22-23=-1169/148, 23-24=-1169/148, 24-25=-1169/148, 25-26=-888/0
BOT CHORD 48-49=0/1314, 46-48=0/2719, 45-46=0/3691, 44-45=0/4140, 43-44=0/4140, 42-43=0/4140, 40-42=0/3028, 38-40=0/1630, 37-38=-444/0, 36-37=-1634/0, 35-36=-1634/0, 33-35=-1430/0, 32-33=-864/0, 31-32=-425/820, 30-31=-148/1169, 29-30=0/1150, 28-29=0/575
WEBS 2-49=-1517/0, 2-48=0/895, 3-48=-933/0, 3-46=0/703, 14-37=-1885/0, 14-38=0/1192, 13-38=-1197/0, 13-40=0/992, 10-40=-782/0, 10-42=0/667, 8-42=-886/0, 5-46=-509/0, 5-45=0/422, 7-45=-474/164, 18-33=-388/104, 18-35=-260/204, 16-37=-762/0, 21-33=-1021/0, 21-32=0/671, 22-32=-709/0, 22-31=0/690, 23-31=-303/0, 26-28=-719/0, 26-29=0/407, 25-29=-342/60

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 5) CAUTION, Do not erect truss backwards.



April 9, 2024

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPH Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek	164784333
J0424-2035	F10	Floor	5	1	Job Reference (optional)	

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:20 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f





Plate Offsets (X, Y)--	[16:0-1-8,Edge], [30:0-1-8,Edge], [31:0-1-8,Edge], [35:0-1-8,Edge], [43:0-3-0,0-0-0], [44:0-3-0,Edge]				
LOADING (psf)	SPACING- 1-7-3	CSI.	DEFL. in (loc) l/defl L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL 1.00	TC 0.82	Vert(LL) -0.27 44 >922 480	MT20	244/190
TCDL 10.0	Lumber DOL 1.00	BC 0.56	Vert(CT) -0.37 44 >675 360		
BCLL 0.0	Rep Stress Incr YES	WB 0.57	Horz(CT) 0.05 37 n/a n/a		
BCDL 5.0	Code IRC2015/TP12014	Matrix-S		Weight: 224 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. All bearings 0-3-8 except (jt=length) 33=0-5-8.
(lb) - Max Grav All reactions 250 lb or less at joint(s) except 49=827(LC 3), 37=1389(LC 3), 33=931(LC 4), 28=470(LC 4)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-2002/0, 3-4=-3283/0, 4-5=-3283/0, 5-7=-3970/0, 7-8=-4140/0, 8-10=-3547/0, 10-11=-2413/0, 11-13=-2413/0, 13-14=-721/0, 14-15=0/2013, 15-16=0/2013, 16-17=0/1634, 17-18=0/1634, 18-19=0/1524, 19-21=0/1524, 21-22=-351/655, 22-23=-1169/148, 23-24=-1169/148, 24-25=-1169/148, 25-26=-888/0
BOT CHORD 48-49=0/1314, 46-48=0/2719, 45-46=0/3691, 44-45=0/4140, 43-44=0/4140, 42-43=0/4140, 40-42=0/3028, 38-40=0/1630, 37-38=-444/0, 36-37=-1634/0, 35-36=-1634/0, 33-35=-1430/0, 32-33=-864/0, 31-32=-425/820, 30-31=-148/1169, 29-30=0/1150, 28-29=0/575
WEBS 2-49=-1517/0, 2-48=0/895, 3-48=-933/0, 3-46=0/703, 14-37=-1885/0, 14-38=0/1192, 13-38=-1197/0, 13-40=0/992, 10-40=-782/0, 10-42=0/667, 8-42=-886/0, 5-46=-509/0, 5-45=0/422, 7-45=-474/164, 18-33=-388/104, 18-35=-260/204, 16-37=-762/0, 21-33=-1021/0, 21-32=0/671, 22-32=-709/0, 22-31=0/690, 23-31=-303/0, 26-28=-719/0, 26-29=0/407, 25-29=-342/60

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 5) CAUTION, Do not erect truss backwards.



April 9, 2024

Job J0424-2035	Truss F11	Truss Type Floor	Qty 2	Ply 1	Lot 165 Duncans Creek I64784334
-------------------	--------------	---------------------	----------	----------	------------------------------------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:20 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RIC?PsB70Hq3NSgPqnL8w3uITXbGKWrCDoi7J4zJC?f




Plate Offsets (X,Y)--	[16:0-1-8,Edge], [17:0-1-8,Edge], [28:0-3-0,0-0-0], [29:0-3-0,Edge]
-----------------------	---


LOADING (psf)	SPACING-	1-7-3	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL	1.00	TC 0.77	Vert(LL)	-0.29	29	>856	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.43	Vert(CT)	-0.40	29	>623		
BCLL 0.0	Rep Stress Incr	YES	WB 0.53	Horz(CT)	0.05	22	n/a		
BCDL 5.0	Code IRC2015/TP12014		Matrix-S						
								Weight: 158 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP 2400F 2.0E(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing, Except: 6-0-0 oc bracing: 21-22,20-21,19-20.
WEBS 2x4 SP No.3(flat)	


REACTIONS. (size) 34=0-3-8, 22=0-3-8, 19=Mechanical
 Max Uplift 19=93(LC 3)
 Max Grav 34=876(LC 10), 22=1382(LC 9), 19=222(LC 4)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
 TOP CHORD 2-3=-2140/0, 3-4=-3531/0, 4-5=-3531/0, 5-7=-4367/0, 7-8=-4658/0, 8-10=-4169/0,
 10-11=-3135/0, 11-13=-3135/0, 13-14=-1553/0, 14-15=0/976, 15-16=0/976,
 16-17=-224/391
 BOT CHORD 33-34=0/1396, 31-33=0/2908, 30-31=0/4001, 29-30=0/4658, 28-29=0/4658, 27-28=0/4658,
 25-27=0/3697, 23-25=0/2408, 22-23=0/709, 21-22=-391/224, 20-21=-391/224,
 19-20=-391/224
 WEBS 2-34=-1611/0, 2-33=0/968, 3-33=-1000/0, 3-31=0/778, 14-22=-1796/0, 14-23=0/1111,
 13-23=-1124/0, 13-25=0/916, 10-25=-711/0, 10-27=0/607, 8-27=-799/0, 5-31=-586/0,
 5-30=0/508, 7-30=-623/58, 16-22=-932/0, 17-19=-257/448

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Refer to girder(s) for truss to truss connections.
 - 5) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 93 lb uplift at joint 19.
 - 6) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 7) CAUTION, Do not erect truss backwards.




April 9, 2024

<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TP1 Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	<p>ENGINEERING BY</p>  <p>A MiTek Affiliate</p> <p>818 Soundside Road Edenton, NC 27932</p>
--	--

Job J0424-2035	Truss F12	Truss Type FLOOR	Qty 1	Ply 1	Lot 165 Duncans Creek I64784335
-------------------	--------------	---------------------	----------	----------	------------------------------------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:21 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



	4-5-4 4-5-4	12-10-12 8-5-8	20-10-0 7-11-4
Plate Offsets (X, Y)--	[2:0-1-8,Edge], [3:0-1-8,Edge], [7:0-1-8,Edge], [17:0-1-8,Edge], [18:0-1-8,Edge], [23:0-1-8,Edge]		


LOADING (psf)	SPACING-	1-7-3	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL	1.00	TC 0.31	Vert(LL)	-0.03	16-17	>999	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.25	Vert(CT)	-0.05	16-17	>999		
BCLL 0.0	Rep Stress Incr	YES	WB 0.22	Horz(CT)	0.01	16	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-S						
								Weight: 106 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing, Except: 6-0-0 oc bracing: 19-21,18-19.
WEBS 2x4 SP No.3(flat)	

REACTIONS. All bearings 0-3-8 except (jt=length) 16=Mechanical.
(lb) - Max Grav All reactions 250 lb or less at joint(s) 27 except 24=530(LC 16), 16=324(LC 5), 19=804(LC 11)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 5-6=-635/0, 6-7=-635/0, 7-9=-479/0, 9-10=0/421, 10-11=0/421, 11-12=-538/0, 12-13=-538/0, 13-14=-538/0
BOT CHORD 23-24=0/395, 22-23=0/635, 21-22=0/635, 19-21=-16/273, 18-19=-131/253, 17-18=0/538, 16-17=0/350
WEBS 2-27=-260/0, 3-24=-281/0, 5-24=-456/0, 5-23=0/339, 9-19=-615/0, 9-21=0/306, 7-21=-262/0, 14-16=-439/0, 11-19=-535/0, 11-18=0/453



- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Refer to girder(s) for truss to truss connections.
 - 5) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 6) CAUTION, Do not erect truss backwards.



Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek
J0424-2035	F13	FLOOR	1	1	I64784336
					Job Reference (optional)

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:22 2024 Page 1
 ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



	4-5-4	12-10-12	20-10-0
	4-5-4	8-5-8	7-11-4
Plate Offsets (X, Y)--	[2:0-1-8,Edge], [3:0-1-8,Edge], [7:0-1-8,Edge], [17:0-1-8,Edge], [18:0-1-8,Edge], [23:0-1-8,Edge]		


LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL	1.00	TC 0.37	Vert(LL)	-0.04	16-17	>999	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.30	Vert(CT)	-0.05	16-17	>999		
BCLL 0.0	Rep Stress Incr	YES	WB 0.26	Horz(CT)	0.01	16	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-S						
								Weight: 106 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing, Except: 6-0-0 oc bracing: 19-21,18-19.
WEBS 2x4 SP No.3(flat)	

REACTIONS. All bearings 0-3-8 except (jt=length) 16=Mechanical.
 (lb) - Max Grav All reactions 250 lb or less at joint(s) 27 except 24=689(LC 16), 16=406(LC 5), 19=991(LC 11)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
 TOP CHORD 5-6=-795/0, 6-7=-795/0, 7-9=-614/0, 9-10=0/492, 10-11=0/492, 11-12=-678/0, 12-13=-678/0, 13-14=-678/0
 BOT CHORD 23-24=0/456, 22-23=0/795, 21-22=0/795, 19-21=-14/373, 18-19=-128/324, 17-18=0/678, 16-17=0/439
 WEBS 2-27=-303/0, 3-24=-366/0, 5-24=-594/0, 5-23=0/433, 9-19=-755/0, 9-21=0/367, 7-21=-317/0, 14-16=-551/0, 14-17=-13/305, 11-19=-661/0, 11-18=0/550, 12-18=-285/0


- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Refer to girder(s) for truss to truss connections.
 - 5) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 6) CAUTION, Do not erect truss backwards.




Job J0424-2035	Truss F15-GR	Truss Type FLOOR GIRDER	Qty 1	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	I64784338
-------------------	-----------------	----------------------------	----------	----------	---	-----------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:23 2024 Page 1



Scale = 1:8.5



LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL 1.00	TC 0.12	Vert(LL) -0.00	7	>999	480	MT20	244/190
TCDL 10.0	Lumber DOL 1.00	BC 0.11	Vert(CT) -0.01	7	>999	360		
BCLL 0.0	Rep Stress Incr NO	WB 0.12	Horz(CT) 0.00	5	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014	Matrix-S					Weight: 29 lb	FT = 20%F, 11%E

LUMBER-

TOP CHORD 2x4 SP No.1(flat)
 BOT CHORD 2x4 SP No.1(flat)
 WEBS 2x4 SP No.3(flat)

BRACING-

TOP CHORD Structural wood sheathing directly applied or 3-10-0 oc purlins, except end verticals.
 BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.

REACTIONS.

(size) 8=Mechanical, 5=0-3-8
 Max Grav 8=377(LC 1), 5=543(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.


TOP CHORD 2-3=-429/0
 BOT CHORD 7-8=0/429, 6-7=0/429, 5-6=0/429
 WEBS 3-5=-519/0, 2-8=-519/0

NOTES-

- 1) Unbalanced floor live loads have been considered for this design.
- 2) Plates checked for a plus or minus 1 degree rotation about its center.
- 3) Refer to girder(s) for truss to truss connections.
- 4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
- 5) CAUTION, Do not erect truss backwards.
- 6) Hanger(s) or other connection device(s) shall be provided sufficient to support concentrated load(s) 363 lb down at 1-4-12, and 315 lb down at 3-4-12 on top chord. The design/selection of such connection device(s) is the responsibility of others.
- 7) In the LOAD CASE(S) section, loads applied to the face of the truss are noted as front (F) or back (B).

LOAD CASE(S) Standard

- 1) Dead + Floor Live (balanced): Lumber Increase=1.00, Plate Increase=1.00
 Uniform Loads (plf)
 Vert: 5-8=-8, 1-4=-80
 Concentrated Loads (lb)
 Vert: 2=-326(F) 9=-279(F)



April 9, 2024

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TP1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)




818 Soundside Road
 Edenton, NC 27932

Job J0424-2035	Truss F16	Truss Type FLOOR	Qty 1	Ply 1	Lot 165 Duncans Creek I64784339
					Job Reference (optional)

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:23 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RIC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL	1.00	TC 0.40	Vert(LL)	-0.09 15-16	>999	480	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.47	Vert(CT)	-0.12 15-16	>999	360		
BCLL 0.0	Rep Stress Incr	YES	WB 0.34	Horz(CT)	0.02 14	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-S						
								Weight: 94 lb	FT = 20%F, 11%E


LUMBER-
TOP CHORD 2x4 SP No.1(flat)
BOT CHORD 2x4 SP No.1(flat)
WEBS 2x4 SP No.3(flat)

BRACING-
TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.

REACTIONS. (size) 23=0-3-8, 19=0-3-8, 14=0-3-8
Max Grav 23=281(LC 3), 19=1198(LC 8), 14=631(LC 4)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-327/57, 3-4=-327/57, 4-5=0/707, 5-6=0/707, 6-7=-932/0, 7-8=-1731/0, 8-9=-1731/0, 9-11=-1731/0, 11-12=-1213/0
BOT CHORD 22-23=-57/327, 21-22=-57/327, 19-21=-270/60, 18-19=-132/410, 17-18=0/1433, 16-17=0/1731, 15-16=0/1604, 14-15=0/776
WEBS 2-23=-401/73, 4-19=-625/0, 4-21=0/488, 12-14=-971/0, 12-15=0/569, 11-15=-509/0, 6-19=-1108/0, 6-18=0/710, 7-18=-693/0, 7-17=0/572, 8-17=-259/0, 11-16=-70/307

NOTES-
1) Unbalanced floor live loads have been considered for this design.
2) All plates are 3x4 MT20 unless otherwise indicated.
3) Plates checked for a plus or minus 1 degree rotation about its center.
4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
5) CAUTION, Do not erect truss backwards.



April 9, 2024

<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE. Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbccomponents.com)</p>	 818 Soundside Road Edenton, NC 27932
---	---

Job J0424-2035	Truss F17	Truss Type Floor	Qty 4	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	164784340
-------------------	--------------	---------------------	----------	----------	---	-----------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:24 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f





Plate Offsets (X, Y)--	[11:0-1-8,Edge], [12:0-1-8,Edge]								
LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL 1.00		TC 0.32	Vert(LL) -0.08	12-13	>999	480	MT20	244/190
TCDL 10.0	Lumber DOL 1.00		BC 0.42	Vert(CT) -0.11	12-13	>999	360		
BCLL 0.0	Rep Stress Incr YES		WB 0.30	Horz(CT) 0.02	9	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-S						
								Weight: 63 lb	FT = 20%F, 11%E

LUMBER-		BRACING-	
TOP CHORD 2x4 SP No.1(flat)		TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)		BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)			

REACTIONS. (size) 14=0-3-8, 9=0-3-8
Max Grav 14=672(LC 1), 9=672(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-1311/0, 3-4=-1971/0, 4-5=-1971/0, 5-6=-1971/0, 6-7=-1311/0
BOT CHORD 13-14=0/829, 12-13=0/1757, 11-12=0/1971, 10-11=0/1757, 9-10=0/829
WEBS 2-14=-1038/0, 2-13=0/627, 3-13=-581/0, 3-12=0/472, 7-9=-1038/0, 7-10=0/627, 6-10=-581/0, 6-11=0/472

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) All plates are 3x4 MT20 unless otherwise indicated.
 - 3) Plates checked for a plus or minus 1 degree rotation about its center.
 - 4) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.




<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	<p>ENGINEERING BY</p> <p>TRENCO</p> <p>A MiTek Affiliate</p> <p>818 Soundside Road Edenton, NC 27932</p>
--	---

Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek	I64784341
J0424-2035	F18	Floor	1	1	Job Reference (optional)	

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:24 2024 Page 1
 ID:6XJu5EDhOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f




LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP	
TCLL 40.0	Plate Grip DOL	1.00	TC 0.39	Vert(LL)	-0.10	11-12	>999	480	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.46	Vert(CT)	-0.12	11-12	>999	360		
BCLL 0.0	Rep Stress Incr	YES	WB 0.49	Horz(CT)	0.01	10	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-S							
									Weight: 64 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 10=0-3-8, 1=0-3-8
 Max Grav 10=657(LC 1), 1=663(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
 TOP CHORD 1-2=-837/0, 2-4=-837/0, 4-5=-1880/0, 5-6=-1880/0, 6-7=-1880/0, 7-8=-1276/0
 BOT CHORD 13-14=0/1567, 12-13=0/1880, 11-12=0/1701, 10-11=0/810
 WEBS 1-14=0/1027, 8-10=-1014/0, 8-11=0/606, 7-11=-553/0, 7-12=0/444, 4-14=-818/0, 4-13=0/549, 5-13=-261/0

- NOTES-**
- 1) Unbalanced floor live loads have been considered for this design.
 - 2) Plates checked for a plus or minus 1 degree rotation about its center.
 - 3) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - 4) Gap between inside of top chord bearing and first diagonal or vertical web shall not exceed 0.500in.
 - 5) CAUTION, Do not erect truss backwards.



April 9, 2024


<p>WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.</p> <p>Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see ANSI/TPH Quality Criteria and DSB-22 available from Truss Plate Institute (www.tpinst.org) and BCSI Building Component Safety Information available from the Structural Building Component Association (www.sbcacomponents.com)</p>	<p>ENGINEERING BY</p> <p>TRENCO</p> <p>A MiTek Affiliate</p> <p>818 Soundside Road Edenton, NC 27932</p>
--	--

Job J0424-2035	Truss F19	Truss Type FLOOR	Qty 1	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	I64784342
-------------------	--------------	---------------------	----------	----------	---	-----------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:24 2024 Page 1

ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RIC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f



Scale = 1:7.3

Plate Offsets (X,Y)-- [1:Edge,0-1-8]		CSI.		DEFL.				PLATES	GRIP
LOADING (psf)	SPACING- 2-0-0	TC	0.66	in (loc)	l/defl	L/d	MT20	244/190	
TCLL 40.0	Plate Grip DOL 1.00	BC	0.13	Vert(LL) 0.00	5 ****	480			
TCDL 10.0	Lumber DOL 1.00	WB	0.13	Vert(CT) -0.00	4-5 >999	360			
BCLL 0.0	Rep Stress Incr NO	Matrix-P		Horz(CT) 0.00	4 n/a	n/a			
BCDL 5.0	Code IRC2015/TPI2014						Weight: 16 lb	FT = 20%F, 11%E	

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 2-8-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	

REACTIONS. (size) 5=0-6-15, 4=Mechanical
Max Grav 5=535(LC 1), 4=308(LC 1)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
BOT CHORD 4-5=0/458
WEBS 2-4=-548/0, 2-5=-548/0

NOTES-
1) Plates checked for a plus or minus 1 degree rotation about its center.
2) Refer to girder(s) for truss to truss connections.
3) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
4) CAUTION, Do not erect truss backwards.

LOAD CASE(S) Standard
1) Dead + Floor Live (balanced): Lumber Increase=1.00, Plate Increase=1.00
Uniform Loads (plf)
Vert: 4-5=-10, 1-3=-100
Concentrated Loads (lb)
Vert: 6=-577



April 9, 2024

Job J0424-2035	Truss FKW1	Truss Type Floor Supported Gable	Qty 1	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	164784343
-------------------	---------------	-------------------------------------	----------	----------	---	-----------


Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:25 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f

0-1-8

0-1-8

Scale = 1:37.7




LOADING (psf)		SPACING-		CSI.		DEFL.				PLATES	GRIP	
TCLL	40.0	Plate Grip DOL	1.00	TC	0.06	Vert(LL)	n/a	-	n/a	999	MT20	244/190
TCDL	10.0	Lumber DOL	1.00	BC	0.01	Vert(CT)	n/a	-	n/a	999		
BCLL	0.0	Rep Stress Incr	YES	WB	0.03	Horz(CT)	0.00	20	n/a	n/a		
BCDL	5.0	Code	IRC2015/TPI2014	Matrix-R							Weight: 94 lb	FT = 20%F, 11%E

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.1(flat)	TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD	2x4 SP No.1(flat)	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS	2x4 SP No.3(flat)		
OTHERS	2x4 SP No.3(flat)		

REACTIONS. All bearings 22-7-8.
(lb) - Max Grav All reactions 250 lb or less at joint(s) 38, 20, 37, 36, 35, 34, 33, 32, 30, 29, 28, 27, 26, 25, 24, 23, 22, 21

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- All plates are 1.5x3 MT20 unless otherwise indicated.
 - Plates checked for a plus or minus 1 degree rotation about its center.
 - Gable requires continuous bottom chord bearing.
 - Truss to be fully sheathed from one face or securely braced against lateral movement (i.e. diagonal web).
 - Gable studs spaced at 1-4-0 oc.
 - Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.



April 9, 2024


Job J0424-2035	Truss FKW2	Truss Type Floor Supported Gable	Qty 1	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	164784344
-------------------	---------------	-------------------------------------	----------	----------	---	-----------

Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:25 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f

0-1/8

Scale = 1:30.8



18-6-0
18-6-0


Plate Offsets (X, Y)--	[1:Edge,0-1-8], [32:Edge,0-1-8]				
LOADING (psf)	SPACING- 2-0-0	CSI.	DEFL. in (loc) l/defl L/d	PLATES	GRIP
TCLL 40.0	Plate Grip DOL 1.00	TC 0.06	Vert(LL) n/a - n/a 999	MT20	244/190
TCDL 10.0	Lumber DOL 1.00	BC 0.01	Vert(CT) n/a - n/a 999		
BCLL 0.0	Rep Stress Incr YES	WB 0.03	Horz(CT) 0.00 17 n/a n/a		
BCDL 5.0	Code IRC2015/TPI2014	Matrix-R		Weight: 78 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	
OTHERS 2x4 SP No.3(flat)	

REACTIONS. All bearings 18-6-0.
(lb) - Max Grav All reactions 250 lb or less at joint(s) 32, 17, 31, 30, 29, 27, 26, 25, 24, 23, 22, 21, 20, 19, 18

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- All plates are 1.5x3 MT20 unless otherwise indicated.
 - Plates checked for a plus or minus 1 degree rotation about its center.
 - Gable requires continuous bottom chord bearing.
 - Truss to be fully sheathed from one face or securely braced against lateral movement (i.e. diagonal web).
 - Gable studs spaced at 1-4-0 oc.
 - Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.
 - CAUTION, Do not erect truss backwards.



April 9, 2024

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPH Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)



818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	Lot 165 Duncans Creek	I64784345
J0424-2035	FKW3	Floor Supported Gable	1	1	Job Reference (optional)	


Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:26 2024 Page 1
 ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3ulTXbGKWrCDoi7J4zJC?f

0-1/8

0-1/8

Scale = 1:20.7



12-6-8
12-6-8

Plate Offsets (X,Y)-- [1:Edge,0-1-8]


LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP	
TCLL 40.0	Plate Grip DOL	1.00	TC 0.06	Vert(LL)	n/a	-	n/a	999	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.02	Vert(CT)	n/a	-	n/a	999		
BCLL 0.0	Rep Stress Incr	YES	WB 0.03	Horz(CT)	0.00	12	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-R							
									Weight: 55 lb	FT = 20%F, 11%E

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.1(flat)	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.1(flat)	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3(flat)	
OTHERS 2x4 SP No.3(flat)	

REACTIONS. All bearings 12-6-8.
 (lb) - Max Grav All reactions 250 lb or less at joint(s) 22, 12, 21, 20, 19, 18, 17, 16, 15, 14, 13

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- All plates are 1.5x3 MT20 unless otherwise indicated.
 - Plates checked for a plus or minus 1 degree rotation about its center.
 - Gable requires continuous bottom chord bearing.
 - Truss to be fully sheathed from one face or securely braced against lateral movement (i.e. diagonal web).
 - Gable studs spaced at 1-4-0 oc.
 - Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.



April 9, 2024

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
 Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPH Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)



818 Soundside Road
 Edenton, NC 27932

Job J0424-2035	Truss FKW4	Truss Type Floor Supported Gable	Qty 1	Ply 1	Lot 165 Duncans Creek Job Reference (optional)	164784346
-------------------	---------------	-------------------------------------	----------	----------	---	-----------


Comtech, Inc. Fayetteville, NC - 28314,

8.430 s Jan 6 2022 MiTek Industries, Inc. Tue Apr 9 10:31:26 2024 Page 1
ID:6XJu5EDhIOALdYBK4rF8nKyOFED-RfC?PsB70Hq3NSgPqnL8w3uITXbGKWrCDoi7J4zJC?f

0₁1₈

0₁1₈

Scale = 1:20.7



12-7-0
12-7-0

LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP	
TCLL 40.0	Plate Grip DOL	1.00	TC 0.06	Vert(LL)	n/a	-	n/a	999	MT20	244/190
TCDL 10.0	Lumber DOL	1.00	BC 0.02	Vert(CT)	n/a	-	n/a	999		
BCLL 0.0	Rep Stress Incr	YES	WB 0.03	Horz(CT)	0.00	12	n/a	n/a		
BCDL 5.0	Code IRC2015/TPI2014		Matrix-R							
									Weight: 54 lb	FT = 20%F, 11%E

LUMBER-
TOP CHORD 2x4 SP No.1(flat)
BOT CHORD 2x4 SP No.1(flat)
WEBS 2x4 SP No.3(flat)
OTHERS 2x4 SP No.3(flat)

BRACING-
TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.

REACTIONS. All bearings 12-7-0.
(lb) - Max Grav All reactions 250 lb or less at joint(s) 22, 12, 21, 20, 19, 18, 17, 16, 15, 14, 13

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- 1) All plates are 1.5x3 MT20 unless otherwise indicated.
 - 2) Plates checked for a plus or minus 1 degree rotation about its center.
 - 3) Gable requires continuous bottom chord bearing.
 - 4) Truss to be fully sheathed from one face or securely braced against lateral movement (i.e. diagonal web).
 - 5) Gable studs spaced at 1-4-0 oc.
 - 6) Recommend 2x6 strongbacks, on edge, spaced at 10-0-0 oc and fastened to each truss with 3-10d (0.131" X 3") nails. Strongbacks to be attached to walls at their outer ends or restrained by other means.



April 9, 2024


WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPH Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)




818 Soundside Road
Edenton, NC 27932

Symbols

PLATE LOCATION AND ORIENTATION



Center plate on joint unless x, y offsets are indicated. Dimensions are in ft-in-sixteenths. Apply plates to both sides of truss and fully embed teeth.



For 4 x 2 orientation, locate plates 0- 1/16\" from outside edge of truss.



* Plate location details available in MITek software or upon request.

PLATE SIZE

4 X 4


The first dimension is the plate width measured perpendicular to slots. Second dimension is the length parallel to slots.

LATERAL BRACING LOCATION



Indicated by symbol shown and/or by text in the bracing section of the output. Use T or I bracing if indicated.

BEARING



Indicates location where bearings (supports) occur. Icons vary but reaction section indicates joint number/letter where bearings occur. Min size shown is for crushing only.


Industry Standards:

ANSI/TP1: National Design Specification for Metal Plate Connected Wood Truss Construction.
DSB-22: Design Standard for Bracing.
BCSI: Building Component Safety Information, Guide to Good Practice for Handling, Installing, Restraining & Bracing of Metal Plate Connected Wood Trusses.

Numbering System



1 TOP CHORDS
2 Joint ID
3 typ.



JOINTS ARE GENERALLY NUMBERED/LETTERED CLOCKWISE AROUND THE TRUSS STARTING AT THE JOINT FARTHEST TO THE LEFT.

CHORDS AND WEBS ARE IDENTIFIED BY END JOINT NUMBERS/LETTERS.

Product Code Approvals

ICC-ES Reports:

ESR-1988, ESR-2362, ESR-2685, ESR-3282
ESR-4722, ESL-1388

Design General Notes

Trusses are designed for wind loads in the plane of the truss unless otherwise shown.

Lumber design values are in accordance with ANSI/TP1 section 6.3. These truss designs rely on Lumber values established by others.

© 2023 MITek® All Rights Reserved

General Safety Notes

Failure to Follow Could Cause Property Damage or Personal Injury

1. Additional stability/bracing for truss system, e.g. diagonal or X-bracing, is always required. See BCSI.
2. Truss bracing must be designed by an engineer. For wide truss spacing, individual lateral braces themselves may require bracing, or alternative Tor I bracing should be considered.
3. Never exceed the design loading shown and never stack materials on inadequately braced trusses.
4. Provide copies of this truss design to the building designer, erection supervisor, property owner and all other interested parties.
5. Cut members to bear tightly against each other.
6. Place plates on each face of truss at each joint and embed fully. Knots and wane at joint locations are regulated by ANSI/TP1 1.
7. Design assumes trusses will be suitably protected from the environment in accord with ANSI/TP1 1.
8. Unless otherwise noted, moisture content of lumber shall not exceed 19% at time of fabrication.
9. Unless expressly noted, this design is not applicable for use with fire retardant, preservative treated, or green lumber.
10. Camber is a non-structural consideration and is the responsibility of truss fabricator. General practice is to camber for dead load deflection.
11. Plate type, size, orientation and location dimensions indicated are minimum plating requirements.
12. Lumber used shall be of the species and size, and in all respects, equal to or better than that specified.
13. Top chords must be sheathed or purlins provided at spacing indicated on design.
14. Bottom chords require lateral bracing at 10 ft. spacing, or less, if no ceiling is installed, unless otherwise noted.
15. Connections not shown are the responsibility of others.
16. Do not cut or alter truss member or plate without prior approval of an engineer.
17. Install and load vertically unless indicated otherwise.
18. Use of green or treated lumber may pose unacceptable environmental, health or performance risks. Consult with project engineer before use.
19. Review all portions of this design (front, back, words and pictures) before use. Reviewing pictures alone is not sufficient.
20. Design assumes manufacture in accordance with ANSI/TP1 1 Quality Criteria.
21. The design does not take into account any dynamic or other loads other than those expressly stated.

MITek

ENGINEERING BY
TRENGO
A MITek Affiliate

MITek Engineering Reference Sheet: MIL-7473 rev. 1/2/2023