

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

June 4, 2024

Subject: 79 On Rock Lane
Lillington, NC 27546
Plan Revision Letter
Harnett County Permit # SFD2404-0060

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- The 2 - #4 bars shown on the plans for the continuous footings will not be installed. Removing the rebar from the continuous footings is acceptable.

The continuous footings without the rebar meet all the requirements of the 2018 North Carolina Building Code for Residences.



06 04 2024 EDT