

May 2nd, 2024

DRB Homes NC LLC
3000 RDU Center Drive Ste 202
Morrisville, NC 27560

Re: Status of Permit Application-SFD2404-0072-345 Adams Pointe Circle

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines flagged every 50' and irons that are set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. House Box needs to be marked to match site plan (\$25.00 Fee Incurred)
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs undergrowth cleared, do not disturb the soil
- 5. Driveway not shown on site plan
- 6. Backhoe Pits Required
- 7. **Other – Will need a soil scientist to issue a LSS permit. Soil looks to be disturbed during the clearing process.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy: Central Permitting