

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.

ENOCH ENGINEERS, P.A.

1403 NC Highway 50 South
Benson, North Carolina 27504
919.894.7765

Email: general@enochengineers.com

www.enochengineers.com

MATERIALS & TEST DIVISION FIELD REPORT

PROJECT

CLIENT: LOCKAMY GRADING	DATE: 5.23.24
PROJECT: WEST PRESERVE S/D	CONTRACTOR: B. LOCKAMY
ADDRESS: 304 THISTLE	TECHNICIAN: BLH
LOT #: 15	

TEST SUMMARY

PERFORMED NDT ON RESI BUILDING PAD AT SITE NOTED ABOVE USING A TARGET DENSITY OF 118PCF.
SOIL CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

TESTING RESULTS



SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	100+	118.6	121.6	2.4

RETURN VISIT REQUIRED

YES

NO

TECHNICIAN:

5/23/24

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.