

J.S. THOMPSON  
ENGINEERING, INC

November 14, 2024

Noah Mashburn  
Superior Homes of the Sandhills

Dear Mr. Mashburn:

The "Nashville" plan was reviewed for 1185 Cameron Hill Road in Cameron, North Carolina to address the kitchen wall noted by the inspector.

The "as-built" 2 x 4 @ 16" o.c. exterior wall framed at a 9'-0" height will provide the required support for all applied loads. No modification is required.

Please call me if you have any questions.

Sincerely,

J.S. Thompson Engineering, Inc.  
N.C. License No. C-1733



Matthew G. Strother, P.E.

