Harnett County Environmental Health

File/Permit Number: SFD2404-0112

IMPROVEMENT PERMIT

County: Harnett		
PIN/Lot Identifier: 0663-71-0400.000 Lot 42		
Owner: DRB GROUP NORTH CAROLINA LLC Appl	icant: DRB GROUP NORTH CAROLINA LLC	
Property Location: 170 SHELBY MEADOW LN ANGIER, NC 27501		
Subdivision (if applicable) HONEYCUTT HILLS	t #: 42 Block: Section:	
New ■ Expansion □ System Relocated Structure		
Number of bedrooms: 4 Number of Occupants: 8 Other:		
Design Wastewater Strength: ■ Domestic ☐ High Strength Proposed Design Daily Flow: 480 ☐ GPD Proposed LTAR (Initial):	.35 Proposed LTAR (Repair):35	
Proposed Wastewater System Type*: 25% Reduction System (Ini	tial) Pump Required: Yes No May be required	
Proposed Wastewater System Type*: 25% Reduction System (Re	pair) Pump Required: Yes No May be required	
*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII		
Effluent Standard: ■ DSE		
Saprolite System (Initial): ☐ Yes ■ No Saprolite System (Repair): ☐ Yes ■ No		
Fill System (Initial): Yes No If yes, specify: New Existing (when adding more than 6 inches of fill to system area provide a fill plan)		
Fill System (Repair): Yes No If yes, specify: New Existing (when adding more than 6 inches of fill to system area provide a fill plan)		
Usable Depth to LC (Initial)x: 38" Usable Depth to LC (Repair)x: 38" * Limiting Condition		
Max. Trench Depth (Initial)*: 18"-26" Max. Trench Depth (Repair)*: 18"	-26" * Measured on the downhill side of the trench	
Artificial Drainage Required: Yes No If yes, please specify details:		
Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other:		
Drainfield location meets requirements of Rule .0508: Yes 🔳 No 🗌 Drainfield location meets requirements of Rule .0601: Yes 🔳 No 🗍		
Permit valid for: Five years [site plan submitted pursuant to GS 130A-334(13a)] No expiration [plat submitted pursuant to GS 130A-334(7a)]		
Permit conditions:		
No Foundation or Gutter Drains to be Directed Towards No Cutting or Grading of Soil in Septic or Septic Repair Stub Plumbing at Highest Point.		
Authorized Agent's Printed Name: Ren Levocz	Expiration Date: 6-27-29	
Authorized Agent's Signature: Kor July JUE/15	Date: 6-27-24	
See attached site sketch		

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. <u>This permit is subject to revocation if the site plan, plat, or the intended use changes.</u> The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Harnett County Environmental Health

	File/Permit Number	: SFD2404-0112
CONSTRUCTION AUTHORIZATION		
County: Harnett PIN/Lot Identifier: 0663-71-0400.000 Lot 42		
	P NORTH CAROLINA LLC Applicant: DRB GROUP NORTH C	CAROLINA LLC
	SHELBY MEADOW LN ANGIER, NC 27501	
Facility Type: SFD 39' x		
	Number of Occupants: 8 Other:	
	xpansion Repair System Relocation Change of Use	
Basement?	es No Basement Fixtures? Yes No	
Crawl Space? Ye	es No Slab Foundation? Yes No	
Type of Wastewater Syste	tem* 25% Reduction System (Initial) 25% Reduction System	(Repair)
*Please include system cla	lassification for proposed wastewater system types in accordance with Rule .1301 Table XXXII	
Design Daily Flow: 480 GPD Wastewater Strength: Domestic High Strength Industrial Process Wastewater		
	g Design Utilizing Low-flow Fixtures and Low-flow Technologies (S.L. 2013-413 and 2014-120)? gineering documentation)	Yes No
Effluent Standard:	DSE HSE NSF/ANSI 40 TS-I TS-II RCW	
Type of Water Supply:	Private well Public well Shared well Municipal Supply Spring C	Other:
Installation Requirements		
Septic Tank Size: 1,000	gallons Total Trench/Bed Length: 350' feet Trench/Bed Spacing: 9' feet on companion inches LTAR: 35 gpd/ft² Usable Depth to LC (Initial)x: 38"	center
Trench/Bed Width: 36"	inches LTAR: .35 gpd/ft ² Usable Depth to LC (Initial) ^x : 38"	xLimiting condition
Soil Cover: 6" inches	Slope Corrected Maximum Trench/Bed Depth [‡] : 18"-26" inches * Measured on the dou	wnhill side of the trench
Pump Tank Size (if applica	able): gallons Requires more than one pump?	
Pump Requirements: ft. TDH vs GPM Grease Trap Size (if applicable): gallons		
Distribution Method: ■ Serial		
Artificial Drainage Required: Yes No If yes, please specify details:		
<u>Legal Agreements</u> (If the answer is "Yes" to any type of legal agreements, please attach a copy of the agreement.)		
Multi-party Agreement Required [Rule .0204(g)]: Yes No		
Easement, Right-of-Way, or Encroachment Agreement Required [Rule .0204(d)]: Yes No		
Declaration of Restrictive	e Covenants: Yes No Pre-Construction Conference Required: Yes	□ No ☑
	uired: Yes No Minimum O&M Requirements:	
	ation or Gutter Drains to be Directed Towards Septic System.	
No Cutting or Gradin	ng of Soil in Septic or Septic Repair Area.	
with the attached site ske Construction Authorizatio	NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be setch. This Construction Authorization is subject to revocation if the site plan, plat, or the integral on shall not be affected by a change in ownership of the site. This Construction Authorization And NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.	ended use changes. The
Authorized Agent's Printed	ed Name: Ren Levocz Expiration Date: 6-27-	29
Authorized Agent's Signati		
	Date.	

See attached site sketch

Harnett County Environmental Health

SITE SKETCH

0663-71-0400.000

Permit Number SFD2404-0112

DRB GROUP NORTH CAROLINA LLC

Applicant's Name

Authorized State Agent

HONEYCUTT HILLS Lot 42

Subdivision/Section/Lot Number

6-27-24

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

