

		JUS414	USP	11	NA	16d/3-1/2"	16d/3-1/2"
(\bigcirc	MSH422	USP	10	Varies	10d/3"	10d/3"

Products							
PlotID	Length	Product	Plies	Net Qty			
FRONT GDH	22-00-00	1-3/4"x 11-7/8" LVL Kerto-S	3	3			
FB1	7-00-00	1-3/4"x 14" LVL Kerto-S	2	2			
FB2	6-00-00	1-3/4"x 14" LVL Kerto-S	2	2			
FBB	28-00-00	1-3/4"x 18" LVL Kerto-S	3	3			

Truss Placement Plan SCALE: 1/4"=1'

LOAD CHART FOR JACK STUDS (BASED ON TABLES P502.5(1) & (b))
NUMBER OF JACK STUDS REQUIRED @ EA END OF
HEADER/GIADER

END REACTION
(UP TO)
REQ'D STUDS FOR

5100 2

7650 3

10200 4

12750 5

15300 6

END REACTION
(UP TO)
REQ'D STUDS FOR
(2) PLY HEADER

1700 1 3400 2

5100 3 6800 4 8500 5

10200 6

11900 7 13600 8 15300 9

/4"=1'								
CK STUDS (1) & (b)) D @ EA END OF	BUILDER	A & G Residential	CITY / CO. Coats / Harnett		THIS IS A These truss: the building sheets for ea			
3400 1 6800 2 10200 3 13600 4 17000 5	JOB NAME	Lot 21 Turlington Acres	ADDRESS 62 Regineration 62 Reg	62 Regis Lane	is responsible the overall state walls, and co regarding bre or online @ s Bearing rear prescriptive			
	PLAN	Rose B		Floor				
	SEAL DATE	N/A	DATE REV.	05/05/25	(derived from foundation s than 3000# b be retained t			
	QUOTE#		DRAWN BY	Marshall Naylor	specified in retained to d			
	JOB#	J0425-1936	SALES REP.	Marshall Naylor	Signature			

____ = Indicates Left End of Truss (Reference Engineered Truss Drawing) Do NOT Erect Truss Backwards

S A TRUSS PLACEMENT DIAGRAM ONLY.

russes are designed as individual building components to be incorporated into ling design at the specification of the building designer. See individual design or each truss design identified on the placement drawing. The building designer sible for temporary and permanent bracing of the roof and floor system and for all structure. The design of the truss support structure including headers, beams, d columns is the responsibility of the building designer. For general guidance g bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package @ sbcindustry.com соттесн reactions less than or equal to 3000# are deemed to comply with the live Code requirements. The contractor shall refer to the attached Tables I from the prescriptive Code requirements) to determine the minimum on size and number of wood studs required to support reactions greater 10# but not greater than 15000#. A registered design professional shall ned to design the support system for any reaction that exceeds those d in the attached Tables. A registered design professional shall be to design the support system for all reactions that exceed 15000#. **ROOF & FLOOR TRUSSES & BEAMS**

Marshall Naylor

Marshall Naylor

Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444