



North Carolina Onsite Wastewater Contractor Inspector Certification Board  
 Authorized Onsite Wastewater Evaluator Permit Option for Non-Engineered Systems  
 Notice of Intent (NOI) to Construct

New  Expansion  Repair  Relocation  Relocation of Repair Area

Owner or Legal Representative Information:  
 Name: Raul Garcia  
 Mailing address: 72 Electric Ln City: Sanford State: NC Zip: \_\_\_\_\_  
 Phone: 919-895-9836 Email: garcias.tile.concrete.masonry@gmail.com

Authorized Onsite Wastewater Evaluator Information:  
 Name: Hal Owen Certification #: 10036E  
 Mailing address: PO Box 400 City: Lillington State: NC Zip: 27546  
 Phone: 910-893-8743 Email: hal@halowensoil.com

Site Location Information:  
 Site address: 26 Electric Ln  
 Tax parcel identification number or subdivision lot, block number of property: \_\_\_\_\_  
 PIN 9577-84-3855 County: Harnett

System Information:  
 Wastewater System Type: Ila  
 Daily Design Flow: 600 gpd  
 Sapolite System:  Yes  No Subsurface Operator Required:  Yes  No  
 Water Supply Type:  Private Well  Public Water Supply  Spring  Other: \_\_\_\_\_

Facility Type:  
 Residential 5 # Bedrooms 10 Maximum # of Occupants  
 Business Type of Business and Basis for Flow: \_\_\_\_\_  
 Public Assembly Type of Public Assembly and Basis for Flow: \_\_\_\_\_

Required Attachments:  
 Plat or Site Plan  
 Evaluation of Soil and Site Features by Licensed Soil Scientist

Attest: On this the 13 day of December, 2024 by signature below I hereby attest that the information required to be included with this NOI to Construct is accurate and complete to the best of my knowledge. Furthermore, I hereby attest that I have adhered to the laws and rules governing onsite wastewater systems in the state of North Carolina.  
 This NOI shall expire on 13 day of December, 2029.  
 Signature of Authorized Onsite Wastewater Evaluator: Hal Owen  
 Signature of Owner or Legal Representative: Raul Garcia

Disclosure: The owner may apply for a building permit for the project upon submitting a complete NOI to Construct and the fee required (if any) to the local health department. An onsite wastewater system authorized by an authorized onsite wastewater evaluator shall be transferable to a new owner with the consent of the authorized onsite wastewater evaluator.

Local Health Department Receipt Acknowledgement:  
 Signature of Local Health Department Representative: \_\_\_\_\_ Date: \_\_\_\_\_



HALOWE1

OP ID: TOW

# CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)  
12/06/2024

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

**IMPORTANT:** If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must have ADDITIONAL INSURED provisions or be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

<b>PRODUCER</b> INSURANCE SERVICE CTR -LILLING LILLINGTON BRANCH OFFICE PO Box 1565 LILLINGTON, NC 27546 DANIEL L. BABB 910-893-5707	<b>CONTACT NAME:</b> SHARON WOODY	
	<b>PHONE (A/C, No, Ext):</b> 910-893-5707	<b>FAX (A/C, No):</b> 910-893-2077
<b>E-MAIL ADDRESS:</b> SWOODY@ISCFAY.COM		
<b>INSURER(S) AFFORDING COVERAGE</b>		<b>NAIC #</b>
<b>INSURER A :</b> STARSTONE NATIONAL		
<b>INSURER B :</b>		
<b>INSURER C :</b>		
<b>INSURER D :</b>		
<b>INSURER E :</b>		
<b>INSURER F :</b>		

**INSURED**  
 HAL OWEN & ASSOCIATES, INC.  
 PO BOX 400  
 LILLINGTON, NC 27546

**COVERAGES**                      **CERTIFICATE NUMBER:**                      **REVISION NUMBER:**





THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.


INSR LTR	TYPE OF INSURANCE	ADDL INSD	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
	COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS-MADE <input type="checkbox"/> OCCUR  GEN'L AGGREGATE LIMIT APPLIES PER: <input type="checkbox"/> POLICY <input type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC OTHER:						EACH OCCURRENCE \$ DAMAGE TO RENTED PREMISES (Ea occurrence) \$ MED EXP (Any one person) \$ PERSONAL & ADV INJURY \$ GENERAL AGGREGATE \$ PRODUCTS - COMP/OP AGG \$ \$
	AUTOMOBILE LIABILITY <input type="checkbox"/> ANY AUTO OWNED AUTOS ONLY <input type="checkbox"/> HIRED AUTOS ONLY <input type="checkbox"/> SCHEDULED AUTOS <input type="checkbox"/> NON-OWNED AUTOS ONLY						COMBINED SINGLE LIMIT (Ea accident) \$ BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE (Per accident) \$ \$
	UMBRELLA LIAB <input type="checkbox"/> OCCUR EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE DED    RETENTION \$						EACH OCCURRENCE \$ AGGREGATE \$ \$
	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) <input type="checkbox"/> Y/N If yes, describe under DESCRIPTION OF OPERATIONS below						PER STATUTE    OTH-ER E.L. EACH ACCIDENT \$ E.L. DISEASE - EA EMPLOYEE \$ E.L. DISEASE - POLICY LIMIT \$
A	PROFESSIONAL LIAB.			42ESP00143901	01/27/2024	01/27/2025	PER OCC. 1,000,000 AGGREGATE 2,000,000

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)


<b>CERTIFICATE HOLDER</b>  RAUL GARCIA 72 ELECTRIC LN SANFORD, NC 27332	<b>CANCELLATION</b>  SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.
	AUTHORIZED REPRESENTATIVE <i>Taylor Wallace</i>

# Legend

-  House
-  Existing Driveway
-  Existing Egress Easement
-  Distances



Hal Owen & Associates Inc.  
 PO Box 400, Lillington, NC 27546  
 www.halowensoil.com  
 919-893-8743



26 Electric Ln  
 Harnett Co., NC  
 6 December 2024



**AOWE EVALUATION**

HAL OWEN ASSOCIATES  
www.halowensoil.com

# HOA-AOWE-2412-01

Issue date 12/13/2024

Expiration 12/13/2029

**APPLICANT INFORMATION**

Name	Raul Garcia		
Mailing Address	72 Electric Ln, Sanford, NC		
E-mail Address	Garcias.Tile.concrete.masonry@gmail	Telephone Number	919-895-9836

**PROPERTY IDENTIFIERS**

County	Harnett	PIN	9577-84-3855
Size (Acre)	1.845	County PID	
Site Address	26 Electric Ln		
S/D Name and Lot#			

**PROJECT INFORMATION**

Wastewater System	New	.0403 Eng Low Flow	No
Wastewater Strength	Domestic	Effluent Standard	DSE
Facility Type	Residential	Water Supply	Public Water
Design Wastewater Flow	600 gpd	gal/unit	120
Basis for Flow	5 bedrooms	max occupancy	10
Basement	No	Fixtures in basement?	No
Crawl Space	Yes	Slab Foundation	No

**CONSULTANT INFORMATION**

Company Name	Hal Owen & Associates, Inc.		
Mailing Address	PO Box 400, Lillington, NC 27546		
E-mail Address	hal@halowensoil.com	Telephone Number	910-893-8743
Licensed Soil Scientist	Britt Wilson, LSS#1351	AOWE	Hal Owen, #10036E

A soil and site evaluation has been conducted for the referenced property for the purpose of permitting a subsurface wastewater system. This evaluation was prepared based on information provided by the applicant to include the basis for design flow, proposed structure location(s), and property boundaries. Any false, inaccurate, or incomplete information provided by the applicant, owner, or legal representatives may result in denial or revocation of applications, approvals, or permits.

This AOWE Evaluation is being submitted pursuant to and meets the requirements of G.S.130A-336.2. This evaluation includes a soil and site evaluation, specifications, plans, and reports for the site layout and construction of a proposed onsite wastewater system by an Authorized On-Site Wastewater Evaluator (AOWE). The evaluation of soil conditions and site features is provided in accordance with G.S. 130A-335(e), the Rules for "Wastewater Treatment and Dispersal Systems", 15A NCAC 18E, and local septic regulations (if any). This report represents my professional opinion as a Licensed Soil Scientist and Authorized Onsite Wastewater Evaluator.

*Britt Wilson*

*Hal Owen*



# AOWE EVALUATION

HAL OWEN ASSOCIATES  
www.halowensoil.com

## WASTEWATER SYSTEM DESIGN SPECIFICATIONS

Permit # HOA-AOWE-2412-01

Proposed Design Daily Flow	<u>600</u> gpd	Drainfield Meets Requirements:
Septic Tank Size (minimum)	<u>1250</u> gallons	.0508 Available Space <u>Yes</u>
Pump Tank Size (minimum)	<u>1250</u> gallons, if required	.0601 Setbacks <u>Yes</u>

### Initial System

System Type	<u>Ila – Conventional system for a single family of 480 gpd or less</u>	
Pump Required	<u>No</u>	ft TDH at _____ GPM
Trenches:	<u>Conventional</u>	
Design LTAR	<u>0.425</u> gal/day/ft <sup>2</sup>	Saprolite System <u>No</u>
Total Trench/ Bed Length	<u>472</u> feet	Fill System <u>No</u>
Trench Spacing	<u>9</u> ft on center	
Usable soil depth to LC	<u>45</u> inches	
Maximum Trench Depth	<u>20</u> inches, measured on downhill side of trench	
Minimum Soil Cover	<u>6</u> inches	
Artificial Drainage Required	<u>No</u>	

### Repair System

System Type:	<u>IIle – PPBPS gravity system</u>	
Pump Required	<u>No</u>	
Trenches:	<u>PPBPS, horizontal</u>	
Design LTAR	<u>0.35</u> gal/day/ft <sup>2</sup>	Saprolite System <u>Yes</u>
Total Trench/ Bed Length	<u>286</u> feet	Fill System <u>No</u>
Trench Spacing	<u>9</u> ft on center	
Usable soil depth to LC	<u>35</u> inches	
Maximum Trench Depth of	<u>18</u> inches, measured on downhill side of trench	
Minimum Soil Cover	<u>6</u> inches	

Potential Drainlines flagged at site on 9-ft centers.

Line #	Color	Relative Elevation (ft)	Drainline Length(ft)	Field Length(ft)
1	B	97.79	86	88
2	R	97.13	100	110
3	W	96.49	100	129
4	Existing	102.18	54	56
5	Existing	101.74	60	56
6	Existing	100.56	62	64
7	Existing	100.13	60	44
8	Existing	99.21	64	64
9	B	99.44	64	64
10	Y	98.98	64	64
11	R	98.68	44	44
<b>Existing Septic Tank:</b>		<b>103.13</b>		
<b>Reference Elev:</b>		<b>100.00</b>		

Repair

Initial

#### Notes:

- \*No grading or removal of soil in initial or repair areas
- \*Property lines per owner
- \*Trench bottoms shall be level to +/- 1/4" in 10ft
- \*All parts of septic system must meet minimum setbacks

## AOWE EVALUATION

HAL OWEN ASSOCIATES  
www.halowensoil.com

# HOA-AOWE-2412-01

### PERMIT CONDITIONS

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met.

System shall be installed in accordance with the attached Wastewater System Design Specifications. See attached SYSTEM LAYOUT for wastewater system design and location.

Any changes to the site plan or intended use must be approved by Hal Owen & Associates. Permit modification and resubmittal to the LHD may be necessary to ensure regulatory compliance.

Conformance to ALL regulatory setbacks shall be maintained. Local regulations (such as County, well, or riparian ordinances) may require more stringent setbacks than specified in the State septic regulations.

Minimum soil cover of six inches shall be established over dispersal field. Soil cover above the original grade shall be placed at a uniform depth over the entire dispersal field and shall extend laterally five feet beyond the dispersal trench. Site shall be graded to shed water away from field and a vegetative cover established to prevent erosion.

The dispersal field and repair area shall not be subject to vehicular traffic. Vehicular traffic can damage soils, pipes, and valve boxes. Do not use septic areas for parking.

Do not allow underground utilities, water lines, or sprinkler systems to be installed in the septic areas. Damage to the septic areas could result in the septic permit being revoked.

The wastewater system shall not be covered until inspected by Hal Owen & Associates and shall not be placed into use until an Authorization to Operate is issued.

### SPECIFIC REQUIREMENTS

A pre-construction conference with the septic contractor is required prior to installation. Call Hal Owen & Associates at least five days in advance to schedule 910-893-8743

The inlet and outlet of all tanks shall be equipped with an approved pipe penetration boot.

A pump tank should be added if gravity distribution cannot be demonstrated.


The existing septic tank will need to be replaced with a larger 1250 gallon tank.

The existing system is composed of five unequal length gravel drainlines, totaling 300'. There will be three new gravel drainlines installed off contour (not to exceed 12 inches), totaling 172'.

Notes:  
 \*No grading or removal of soil in initial or repair areas  
 \*Property lines per owner  
 \*Trench bottoms shall be level to +/- 1/4" in 10ft



- Legend**
- House
  - Existing Driveway
  - Reference Elevation
  - Distances
  - Septic Components**
  - Septic Tank
  - Drainlines**
  - Existing
  - Initial
  - Repair
  - Supply Line
  - Existing Egress Easement




Daily Design Flow: 600 gpd


**Initial System:**  
 Gravity to 1 X 472' (x3ft) Lines 4-11  
 Conventional Gravel System  
 Installed off contour (NTE 12"), MTD 20"  
 LTAR 0.425 gal/day/sqft

**Repair System:**  
 PM to 286' (x3ft) Lines 1-3  
 Horizontal PPBPS (50% reduction system)  
 Installed on contour, MTD 18"  
 LTAR 0.35 gal/day/sqft

Hal Owen & Associates Inc.  
 PO Box 400, Lillington, NC 27546  
 www.halowensoil.com  
 919-893-8743



26 Electric Ln  
 Harnett Co., NC  
 13 December 2024



**INITIAL WASTEWATER SYSTEM**

Permit # HOA-AOWE-2412-01

**Gravity System Design Criteria**

**DESIGN DAILY FLOW**      600 gallons


**SOIL LTAR:** 0.425 gpd/ft<sup>2</sup>

**TANK (minimum) Septic Tank:** 1250 gallons

**SUPPLY LINE**      Length (ft): 3      Diameter: 3 " sch 40 pvc  
slope = 3.89%      \*minimum slope of supply line is 1/8" per foot (%1.04)

**TRENCHES**      Drainline Type: Conventional  
Maximum Trench Depth of 20 inches, measured on downhill side  
Trench height: 12 inches      Trench width: 3 ft  
Trench Length Factor: 100 %      Effective Trench Width: 3 ft  
Absorption Area: 1412 ft<sup>2</sup>      Minimum Linear Length: 471 ft  
Actual Trench Length: 1 X 472 ft = 472 ft

**Gravity Distribution Schematic**














\*Outlet depth of septic tank is dependant upon the depth of the plumbing stub out from the home.  
A pump tank should be added if gravity distribution cannot be demonstrated.





# Legend

-  House
-  Existing Driveway
-  Existing Egress Easement
- Soil Unit**
-  Suitable
-  Suitable for Modified Drainlines
-  Unsuitable
- Soil Borings**
-  Soil Profiles
-  Suitable Soils
-  Suitable Soils for Modified Systems
-  Unsuitable Soils



Hal Owen & Associates Inc.  
 PO Box 400, Lillington, NC 27546  
 www.halowensoil.com  
 919-893-8743

0 60 120 ft



For reference only. Not a survey.



26 Electric Ln  
 2 December 2024

Soil Map for Septic Suitability

# AOWE EVALUATION

HAL OWEN ASSOCIATES  
www.halowensoil.com

Permit # HOA-AOWE-2412-01

## SOIL/SITE EVALUATION FORM FOR ON-SITE WASTEWATER SYSTEM

OWNER NAME: Raul Garcia  
 PROPOSED FACILITY: Residential DESIGN DAILY FLOW: 600 WATER SUPPLY Public Water  
 LOCATION OF SITE: 26 Electric Ln PIN: 9577-84-3855  
 WASTEWATER TYPE: Domestic COUNTY: Harnett  
 EVALUATION METHOD: AUGER BORING  PIT  CUT   
 EVALUATED BY: Britt Wilson, LSS#1351 DATE EVALUATED: 11/26/24

	INITIAL SYSTEM	REPAIR SYSTEM
AVAILABLE SPACE	1412 ft <sup>2</sup> trench bottom	857 ft <sup>2</sup> trench bottom
SYSTEM TYPE	Conventional	PPBPS, horizontal
SITE LTAR	0.425 gpd/ft <sup>2</sup>	0.35 gpd/ft <sup>2</sup>
MAX TRENCH DEPTH	20 inches (measured on downhill side)	18 inches (measured on downhill side)
SITE CLASSIFICATION	<u>Suitable</u>	OTHER FACTORS _____

COMMENTS:

### PROFILE 1

HORIZON DEPTH	COLOR	CONSI TENCE	TEXTURE	STRUCTURE	MINERA LOGY	OTHER PROFILE FACTORS	
0-6	10YR 4/2	VFR	SL	GR	SEXP	LANDSCAPE POSITION	CV
6-10	10YR 6/3	FR	SL	SBK	SEXP	SOIL WETNESS DEPTH	35"
10-17	10YR 6/6	FI	SCL	SBK	SEXP	SOIL WETNESS COLOR	10YR 7/2
17-25	10YR 6/4	FR	CL	SBK	SEXP	SOIL DEPTH	25"
25-50+	Varigated	FR	L	M	SEXP	SAPROLITE CLASS	S
						RESTRICTIVE HORIZON	NA
						SLOPE %	7
PROFILE CLASSIFICATION			<b>Suitable</b>	LTAR gpd/ft <sup>2</sup>	<b>0.35</b>	SLOPE CORRECTION (IN)	2.5
COMMENT		Suitable for modified systems					

### PROFILE 2

HORIZON DEPTH	COLOR	CONSI TENCE	TEXTURE	STRUCTURE	MINERA LOGY	OTHER PROFILE FACTORS	
0-13	10YR 5/3	VFR	LS	GR	SEXP	LANDSCAPE POSITION	L
13-28	2.5Y 7/4	VFR	LS	GR	SEXP	SOIL WETNESS DEPTH	45"
28-35	10YR 6/4	FR	SCL	SBK	SEXP	SOIL WETNESS COLOR	10YR 7/1
35-48+	10YR 6/6	FI	SCL	SBK	SEXP	SOIL DEPTH	48"
						SAPROLITE CLASS	NA
						RESTRICTIVE HORIZON	NA
						SLOPE %	4
PROFILE CLASSIFICATION			<b>Suitable</b>	LTAR gpd/ft <sup>2</sup>	<b>0.425</b>	SLOPE CORRECTION (IN)	1.4
COMMENT							

**SOIL/SITE EVALUATION FORM FOR ON-SITE WASTEWATER SYSTEM**

**LEGEND OF ABBREVIATIONS**

<b>LANDSCAPE POSITION</b>	<b>TEXTURE GROUP</b>	<b>TEXTURE CLASS</b>	<b>LTAR (gal/day/sqft)</b>
CC - Concave Slope	I	S - Sand	1.2-0.8
CV - Convex Slope		LS - Loamy Sand	
DS - Debris Slump	II	SL - Sandy Loam	0.8 - 0.6
D - Depression		L - Loam	
DW - Drainage Way			
FP - Flood Plain	III	SCL - Sandy Clay Loam	0.6 - 0.3
FS - Foot Slope		CL - Clay Loam	
H - Head Slope		SiL - Silt Loam	
L - Linear Slope		Si - Silt	
N - Nose Slope		SiCL - Silt Clay Loam	
R - Ridge	IV	SC - Sandy Clay	0.4 - 0.1
S - Shoulder Slope		C - Clay	
T - Terrace		SiC - Silty Clay	
TS - Toe Slope			
		O - Organic	none

<b>STRUCTURE</b>	<b>MOIST CONSISTENCE</b>	<b>WET CONSISTENCE</b>
G - Single Grain	VFR - Very Friable	NS - Non Stick
M - Massive	FR - Friable	SS - Slightly Sticky
CR - Crumb	FI - Firm	MS - Moderately Stick
GR - Granular	VFI - Very Firm	VS - Very Sticky
SBK - Subangular Blocky	EFI - Extremely Firm	
ABK - Angular Blocky		NP - Non Plastic
PL - Platy	<b>MINERALOGY</b>	SP - Slightly Plastic
PR - Prismatic	SEXP - Slightly Expansive	MP - Moderately Plastic
	EXP - Expansive	VP - Very Plastic

<b>MOTTLES</b>			
	f - few	1 - fine	F - Faint
	c - common	2 - medium	D - Distinct
	m - many	3 - coarse	P - Prominent

Give Horizon Depth in inches below natural soil surface and Fill Depth in inches above land surface.

Depth to Soil Wetness: inches below land surface to free water or to soil colors with chroma 2 or less.

Classification: S - Suitable U - Unsuitable

All soil characteristics were described in accordance with the USDA Field Book for Describing and Sampling Soils. The soils were evaluated under moist soil conditions. This evaluation included observations of topography and landscape position, soil morphology (texture, structure, clay mineralogy, organics), soil wetness, soil depth, and restrictive horizons.

## TERMS AND CONDITIONS

This AOWE Evaluation is intended to file a Notice of Intent to construct a wastewater system with the Local Health Department and shall expire in five years. This evaluation is not a permit to develop. The owner and subcontractors will need to abide by all state and local rules and regulations pertaining to planning, zoning, and land use development.

Notice of Intent to Construct – Prior to commencing or assisting in the construction, siting, relocation, or repair of a wastewater system, a complete Notice of Intent (NOI) to Construct a wastewater system using an AOWE must be submitted to the Local Health Department (LHD). The owner may apply for a building permit for the project upon submitting a complete NOI and the required fee.

Plan Alterations – If there are any changes in the site plan that can impact the wastewater system, such as moving the house or driveway, site alterations, or if the applicant chooses to change the design daily flow prior to wastewater system construction, a new NOI shall be submitted to the LHD. The applicant shall request in writing that the PE or AOWE invalidate the prior NOI with a signed and sealed letter sent to the applicant and LHD.

Site Alterations – The applicant shall be responsible for preventing modifications or alterations of the site for the wastewater system and the system repair area before, during, and after any construction activities for the facility, unless approved by the AOWE.

On-Site Wastewater System Contractor – The AOWE shall assist the owner in the selection of a certified on-site wastewater system contractor who shall be under contractual obligation to the owner and have sufficient errors and omissions, liability, or other insurance for the system constructed.

Inspections, Construction Observations, and Reports – The AOWE shall make periodic visits to the site to observe the progress and quality of the construction of the wastewater system.

Authorization to Operate (ATO) – Upon determining that the wastewater system has been properly installed and is capable of being operated in accordance with the conditions of the permit, the AOWE shall provide the owner with a report that includes inspection reports, a written operation and management program, any special reports, and an Authorization to Operate. The owner shall sign confirming acceptance and receipt of the report, and then provide a copy to the LHD who will issue the certificate of occupancy for the facility.

Operation and Management – The owner shall be responsible for continued adherence to the operations and management program established by the AOWE. This permit shall in no way be taken as a guarantee or implied warranty that the septic system will function satisfactorily for any given period of time.

Change in System Ownership – An authorized wastewater system shall be transferrable to a new owner with the consent of the AOWE. The new owner and the AOWE shall enter a contract for the wastewater system.

Revocation – The AOWE permit is subject to revocation if the site plan, plat, or the intended use changes. This permit is subject to compliance with the provisions of the laws and Rules for Wastewater Treatment and Dispersal Systems and to the conditions of this permit.

Repair of Malfunctioning Systems – The owner may apply for an Improvement Permit and a Construction Authorization from the LHD or obtain a NOI from an AOWE to repair a malfunctioning wastewater system.