

Application # _____

Harnett County Central Permitting

420 McKinney Pkwy / PO Box 65 Lillington, NC 27546 - centralpermitting@harnett.org
Ph.: 910-893-7525 - Fax: 910-893-2793 / www.harnett.org/permits

Certification of Work Performed By Owner/Contractor (Individual Trade Application)

Owner (s) of Structure: Dees Homes Phone: _____

Owner (s) Mailing Address: 8521 Six Forks Rd
Raleigh NC

Land Owner Name (s): Dees Homes Phone: _____

Construction or Site Address: 74 Looping Ct Angier NC

PIN # _____ Parcel # _____

Job Cost (Required): 800⁰⁰ Description of Work to be done
Buy 500gal propane tank & line to stub out

Mechanical: New Unit With Ductwork ___ New Unit Without Ductwork ___ Gas Piping Other ___

Electrical*: 200 Amp ___ <200 Amp ___ Service Change ___ Service Reconnect ___ Other ___
* For Progress Energy customers we need the premise number

Plumbing: Water/Sewer Tap ___ Number of Baths ___ Water Heater ___

Specific Directions to Job from Lillington:

Subdivision: _____ Lot #: _____

I Hunter oil & propane will provide the Mechanical labor on this structure.
(Contractors Name) (Trade)

I am the building owner or my NC state license number is 22196, which entitles me to perform such work on the above structure legally. All work shall comply with the State Building Code and all other applicable State and local laws, ordinances and regulations.

Hunter oil & Propane
Contractor's Company Name

1203 S. Hanes Blvd Sanford
Address

22196
License #

919-775-5651
Telephone

richardhunteroil@gmail
Email Address

Structure Owner / Contractor Signature: [Signature] Date: 7-24-24

By signing this application you affirm that you have obtained permission from the above listed license holder to purchase permits on their behalf. If doing the work as owner you understand that you cannot rent, lease or sell the listed property for 12 months after completion of the listed work

***Company name, address, & phone must match information on license**

Faxed or Mailed application could have an approximately 1-5 day process time



ALTERNATE INSPECTIONS FOR LP GAS PIPINGSYSTEM FOR RESIDENTIAL
STRUCTURES

July 24, 2024

To: Harnett County Inspections

From: Hunter Oil and Propane, Lic. # 22196

RE: 74 Looping Ct Angier NC

Please be advised that we hereby certify that 80 feet of LP gas line was buried at or below the minimum depth required by North Carolina Code #404.12 Minimum Burial Depth. In addition we also hereby certify that approved materials were used and the line was pressurized to 65 PSI for 45 minutes in accordance with NC GS 143-139.3. Inspection of LPG 2417.1.

A handwritten signature in black ink, appearing to be "J. Hunter", written over a horizontal line.

Signed by Licensed Contractor performing work