

**J.S. THOMPSON**  
ENGINEERING, INC

September 5, 2024

Ryan Coombs  
H.H. Hunt Homes of Raleigh-Durham  
1401 Sunday Drive Suite 109  
Raleigh, NC 27607

Dear Mr. Coombs:

The "Franklin" plan was reviewed for lot #9 Magnolia Acres subdivision in Fuquay-Varina, North Carolina to address the garage beam.

The "as-built" (2) 1 3/4" x 24" LVL above the garage bearing on the LVL plate in lieu of bearing directly on the jacks per plan is suitable. This configuration will provide the required support for all applied loads.

Please call me if you have any questions.


Sincerely,

J.S. Thompson Engineering, Inc.  
N.C. License No. C-1733



Joshua A. Grantham, E.I.

Matthew G. Strother, P.E.



9/5/2024