

## PROFESSIONAL ENGINEERING SERVICES

3212 Mill Run, Raleigh NC 27612  
North Carolina License 021195

CONSULTING.DESIGN  
P (919) 749.5151

[ottel@yahoo.com](mailto:ottel@yahoo.com)

September 09, 2025

Ref: Structural Evaluation of:  
Knee Wall above Garage Beam

Address: 158 Cubillos Way,,  
Fuquay Varina, NC 27526

To: Icon Contractors Inc.,/Whom it may concern

On September 09, 2025, I visited the above listed property to check the knee wall that recently installed above the front beam, span the opening of the two car garage at the above address.

The knee wall was over 4 feet in height; however the construction of the knee wall was adequate in installation and in the fasteners used that should perform adequately in accordance with engineering design requirements.

All work should be in compliance with 2018 NCBC.

Should you have any questions or concerns regarding the information contained in this report, please contact me at: 919-749-5151.

Sincerely,

Kamal Essaid PE

