



Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

July 1<sup>st</sup>, 2024

Family Building Company II LLC  
1016 Mockingbird Drive  
Raleigh, NC 27615

**Re: Status of Permit Application-SFD2406-0030**

**To whom it may concern,**

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines every 50'. (\$25.00 Fee incurred)
- 2. House Box needs to be marked, pool and proposed shed, (currently there are overlapping layouts and nothing is labeled.) (25.00 Fee Incurred)
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs undergrowth cleared, do not disturb the soil
- 5. Driveway not shown on site plan
- 6. Backhoe Pits Required-
- 7. **Other – Must apply for a well abandonment with our office to free up space for septic. Recommended to revise the application and site plan to have the house box moved 15' to 25' towards the back of property to free up space for septic. Have driveway marked/demonstrated to determine exactly how much septic space is available.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Reynold Levocz R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

RL/kh

Copy: Central Permitting