

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

September 6th, 2024

Shepherd Response LLC
401 E Main St STE 200
Clayton, NC 27520

RE: Existing Tank Application #SFD2406-0034

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank fully and break seal, replace sanitary Tee if it's bad. (\$25.00 fee incurred).

2. Have system pumped out

3. Need site plan

4. Other – Will need property irons, property lines and drain lines.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MO/kh
Copy - Central Permitting