

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.

# ENOCH ENGINEERS, P.A.

1403 NC Highway 50 South  
Benson, North Carolina 27504  
919.894.7765

Email: [general@enochengineers.com](mailto:general@enochengineers.com)

[www.enochengineers.com](http://www.enochengineers.com)

## MATERIALS & TEST DIVISION

### FIELD REPORT

#### PROJECT

CLIENT: LOCKAMY GRADING

DATE: 5.23.24

PROJECT: WEST POINTE S/D

CONTRACTOR: B. LOCKAMY

ADDRESS:

TECHNICIAN: BLH

LOT #: 41

#### TEST SUMMARY

PERFORMED NDT ON RESI BUILDING PAD AT SITE NOTED ABOVE USING A TARGET DENSITY OF 110PCF.

SOIL CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

#### TESTING RESULTS



SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	99.15	109.1	111.6	2.3

#### RETURN VISIT REQUIRED

YES

NO

TECHNICIAN:

5/25/24

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.