

July 15, 2024

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Ally Moss
1101 Slater Road Ste 300
Durham NC 27703

ph: 910-893-7550
fax: 910-893-9429

Re: Status of Improvement Permit Application: SFD2406-0104

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other: Due to soil and available space a 5 bedroom house will not work. A 4 bedroom will but will be a tight fit. Recommended for a 3 bedroom house.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Reynold Levocz, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

RL/slc
Copy: Central Permitting