



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

2/3/2025

**SUBJECT: SFD2406-0128**  
**SINGLE FAMILY DWELLING**

To: Chirs Blackman

Here are the results of all Inspections located at **170 HAWK LN:**

Inspection Type: FOUNDATION SURVEY  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: CP Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: GAS PIPING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: INSULATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: T-POLE  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL SFD STEMWALL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ADDRESS  
Scheduled Date/Time: 6/27/2024  
Completed Date/Time: 6/28/2024  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 2nd home on property  
170 HAWK LN FUQUAY VARINA 27526.

Inspection Type: FOOTING  
Scheduled Date/Time: 8/13/2024  
Completed Date/Time: 8/13/2024  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks:  
Notes: Footing full of water Please post address onsite

Inspection Type: FOOTING  
Scheduled Date/Time: 8/15/2024  
Completed Date/Time: 8/15/2024  
Inspector: Deen Taylor  
Result: DISAPPROVED  
Remarks:  
Notes: All wet/loose soils must be removed from footing or an engineered soil. Report must be provided.

Inspection Type: FOOTING  
Scheduled Date/Time: 8/21/2024  
Completed Date/Time: 8/21/2024  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOUNDATION  
Scheduled Date/Time: 9/13/2024  
Completed Date/Time: 9/13/2024  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks:  
Notes: unable to see projections does to trenches being full of water

Inspection Type: FOUNDATION  
Scheduled Date/Time: 9/16/2024  
Completed Date/Time: 9/16/2024  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: UNDER SLAB TRADES  
Scheduled Date/Time: 9/24/2024  
Completed Date/Time: 9/24/2024  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time: 10/3/2024  
Completed Date/Time: 10/3/2024  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT  
Scheduled Date/Time: 10/21/2024  
Completed Date/Time: 10/21/2024  
Inspector: Reynold J Levocz  
Result: APPROVED  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 12/10/2024  
Completed Date/Time: 12/10/2024  
Inspector: Deen Taylor  
Result: DISAPPROVED

Remarks:

Notes: Customer requesting sheathing; partial framing inspection.

We do not perform sheathing inspections. At the time of the four trade rough in all windows, exterior doors, and roofing must be completed. Siding may be installed at the time of the rough in inspection, but all structural elements/connections must remain exposed until rough in inspection is completed.

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time: 12/13/2024  
Completed Date/Time: 12/13/2024  
Inspector: Justin Ryan McLeod  
Result: CANCELLED

Remarks:

Notes: Partial roughin wall sheathing/plywood.

Inspection Type: ROUGH IN  
Scheduled Date/Time: 1/31/2025  
Completed Date/Time: 1/31/2025  
Inspector: Justin Ryan McLeod  
Result: DISAPPROVED

Remarks:

Notes: 1. Missing all windows. 2. Missing tyvek in various places. 3. Plumbing supply pressure almost at Ops. 4. Plan states lvl at garage doors to be full length. 5. Verify at portal framing the anchoring was done per the engineer letter. 6. verify anchor bolts each side of middle door. 7. Drain leaking by p trap rear left garage. 8. Fireblock top of left wall upstairs. 9. balloon framed gable wall has no top plate. 10. Ridge needs furring down to match the rafter depth. 11. Garage layout plan shows a lvl above dryer area?. 12. Winder tread not per code. Must have 4" minimum. 13. Small rear Deck band attach to house per appendix m. Note waterlines in garage that will not be covered with insulation or exposed outside of walls will need to be insulated.

