

J.S. THOMPSON  
ENGINEERING, INC

September 5, 2024

Bryant Lockamy  
Southern Touch Homes, LLC  
1940 County Line Road  
Angier, NC 27501

Dear Mr. Lockamy:

The "Wells" plan was reviewed for lot #43 West Preserve subdivision (116 Boyce Ct.) in Sanford, North Carolina to address adding a cased opening between the garages.

A 8/0 cased opening with a (2) 1 3/4" x 9 1/4" LVL header may be added in the location between the garages indicated on the architectural plan (see excerpt below). The LVL header is to be supported by (2) SPF #2 jacks and (1) SPF #2 king stud at each end. The continuous lug footing beneath the opening is suitable per plan. This configuration will provide the required support for all applied loads.

Please call me if you have any questions.

Sincerely,

J.S. Thompson Engineering, Inc.  
N.C. License No. C-1733

Joshua A. Grantham, E.I.

Matthew G. Strother, P.E.

