



STICK FRAMING REQUIRED

Hatch Legend	
	DROP WALLS 1'-7" BELOW TYP
	Vaulted Ceiling

Products				
PlotID	Length	Product	Plies	Net Qty
BM1 FLUSH	6' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	2
GDH DROPPED	22' 0"	1-3/4"x 11-7/8" LVL Kerto-S	2	2

- GENERAL NOTES
1. WALL HEIGHT IS 8' 1-1/2" (1' 7" BELOW TYP)
 2. ALL TRAYS BUILT DOWN BY BUILDER
 3. G5L TRUSS IS ABLE TO SHIFT SPACING TO MAKE STAIRS WORK

Connector Information				Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Truss
	HUS26	USP	3	NA	16d/3-1/2" 16d/3-1/2"

Hatch Legend	
	DROP WALLS 1'-7" BELOW TYP
	Vaulted Ceiling

Products				
PlotID	Length	Product	Plies	Net Qty
BM1 FLUSH	6' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	2
GDH DROPPED	22' 0"	1-3/4"x 11-7/8" LVL Kerto-S	2	2

- GENERAL NOTES
1. WALL HEIGHT IS 8' 1-1/2" (1' 7" BELOW TYP)
 2. ALL TRAYS BUILT DOWN BY BUILDER
 3. G5L TRUSS IS ABLE TO SHIFT SPACING TO MAKE STAIRS WORK

Connector Information				Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Truss
	HUS26	USP	3	NA	16d/3-1/2" 16d/3-1/2"

Truss Placement Plan
SCALE: NTS

= Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards

LOAD CHART FOR JACK STUDS

(BASED ON TABLES B502.5(1) & (2))
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADQUORSE

END REACTION (UP TO) @ END OF HEADQUORSE	END REACTION (UP TO) @ END OF HEADQUORSE	END REACTION (UP TO) @ END OF HEADQUORSE
1700	2550	3400
3400	5100	6800
5100	7650	10200
6800	10200	13600
8500	12750	17000
10200	15300	
11900		
13600		
15300		

BUILDER	GMC Construction	CITY / CO.	Tar Heel / Bladen
JOB NAME	Lot 2 River Road	ADDRESS	Lot 2 River Road
PLAN	Hazelwood (Modified)	MODEL	Roof
SEAL DATE	Seal Date	DATE REV.	08/21/24
QUOTE #	B0824-4548	DRAWN BY	Michael Turner
JOB #	J0824-4548	SALES REP.	Scot Duncan

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSH-B1 and BCSH-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature: Michael Turner
Michael Turner

ROOF & FLOOR TRUSSES & BEAMS

Reilly Road Industrial Park
Fayetteville, N.C. 28309
Phone: (910) 864-8787
Fax: (910) 864-4444