Harnett County Environmental Health

File/Permit Number: BRES2408-0011 & SFD2408-0028

IMPROVEMENT PERMIT

County: Harnett
PIN/Lot Identifier: 0652-08-6755.000 Lot 2
Dwner: NEUMANN DAVID E & RABIDEAU MADELINE M Applicant: Butler Homes
Property Location: 127 WESLEY CIR FUQUAY-VARINA, NC 27526
Subdivision (if applicable) Lot #: 2 Block: Section:
New ■ Expansion ☐ System Relocation ☐ Change of Use ☐
Facility Type: SFD 40' x 56' & Detached Garage 24' x 24'
Number of bedrooms: 3 Number of Occupants: 6 Other:
Design Wastewater Strength: Domestic High Strength Industrial Process Wastewater
Proposed Design Daily Flow: 360 GPD Proposed LTAR (Initial): 3 Proposed LTAR (Repair): 3
Proposed Wastewater System Type*: 25% Reduction System (Initial) Pump Required: Type Yes No May be required
Proposed Wastewater System Type*: 25% Reduction System (Repair) Pump Required: Yes No May be required
*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII
Effluent Standard: DSE HSE NSF/ANSI 40 TS-I TS-II RCW
Saprolite System (Initial): Yes No Saprolite System (Repair): Yes No
Fill System (Initial): 🗌 Yes 🔳 No If yes, specify: 🔲 New 🔲 Existing (when adding more than 6 inches of fill to system area provide a fill plan
Fill System (Repair): 🗌 Yes 🔳 No If yes, specify: 🗌 New 🔲 Existing (when adding more than 6 inches of fill to system area provide a fill plan
Usable Depth to LC (Initial)x: 31" Usable Depth to LC (Repair)x: 31" * Limiting Condition
Max. Trench Depth (Initial)*: 18" Max Max. Trench Depth (Repair)*: 18" Max *Measured on the downhill side of the trench
Artificial Drainage Required: Yes No If yes, please specify details:
Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other:
Orainfield location meets requirements of Rule .0508: Yes 🔳 No 🗌 Drainfield location meets requirements of Rule .0601: Yes 🔳 No 🗍
Permit valid for: 🔳 Five years [site plan submitted pursuant to GS 130A-334(13a)] 🔲 No expiration [plat submitted pursuant to GS 130A-334(7a
Permit conditions:
No Foundation or Gutter Drains to be Directed Towards Septic System.
No Grading or Cutting of Soil in Septic or Septic Repair Area.
Authorized Agent's Printed Name: Ren Levocz Expiration Date: 9-16-29
Authorized Agent's Signature:

See attached site sketch

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. <u>This permit is subject to revocation if the site plan, plat, or the intended use changes.</u> The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Harnett County Environmental Health

File/Permit Number: BRES2408-0011 & SFD2408-00
CONSTRUCTION AUTHORIZATION
County: Harnett PIN/Lot Identifier: 0652-08-6755.000 Lot 2
Owner: NEUMANN DAVID E & RABIDEAU MADELINE M Applicant: Butler Homes
Property Location: 127 WESLEY CIR FUQUAY-VARINA, NC 27526
Facility Type: SFD 40' x 56' & Detached Garage 24' x 24'
Number of bedrooms: 3 Number of Occupants: 6 Other:
■ New
Basement? ☐ Yes ■ No Basement Fixtures? ☐ Yes ■ No
Crawl Space? ■ Yes No Slab Foundation? ☐ Yes ■ No
Type of Wastewater System* 25% Reduction System (Initial) 25% Reduction System (Repo
*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII
Design Daily Flow: 360 GPD Wastewater Strength: Domestic High Strength Industrial Process Wastewater
Rule .0403(e) Engineering Design Utilizing Low-flow Fixtures and Low-flow Technologies (S.L. 2013-413 and 2014-120)?
Effluent Standard: DSE NSF/ANSI 40 TS-I RCW
Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other:
Installation Requirements/Conditions
Septic Tank Size: 1,000 gallons Total Trench/Bed Length: 300' feet Trench/Bed Spacing: 9' feet on center Trench/Bed Width: 36" inches LTAR: 3 gpd/ft² Usable Depth to LC (Initial)x: 31" xLimiting condition Soil Cover: 6" inches Slope Corrected Maximum Trench/Bed Depth to LC (Initial)x: 18" Max inches * Measured on the downhill side of the trench
Pump Tank Size (if applicable): 1,000 gallons Requires more than one pump? Yes No
Pump Requirements: ft. TDH vs GPM Grease Trap Size (if applicable): gallons
Distribution Method: Serial D-Box or Parallel Pressure Manifold(s) LPP Other: 3 100' Lines
Artificial Drainage Required: Yes No I If yes, please specify details:
<u>Legal Agreements</u> (If the answer is "Yes" to any type of legal agreements, please attach a copy of the agreement.)
Multi-party Agreement Required [Rule .0204(g)]: Yes No
Easement, Right-of-Way, or Encroachment Agreement Required [Rule .0204(d)]: Yes No
Declaration of Restrictive Covenants: Yes No Pre-Construction Conference Required: Yes No
Management Entity Required: Yes No Minimum O&M Requirements:
Conditions: No Foundation or Gutter Drains to be Directed Towards Septic System.
No Grading or Cutting of Soil in Septic or Septic Repair Area.
The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. <u>This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.</u> The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliant with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.
Authorized Agent's Printed Name: Ren Levocz Expiration Date: 9-16-29
Authorized Agent's Signature: 12 12 15 Date: 9-16-24

See attached site sketch

Harnett County Environmental Health

SITE SKETCH

0652-08-6755.000

BRES2408-0011 & SFD2408-0028 Permit Number

Butler Homes

Applicant's Name

Authorized State Agent

Lot 2

Subdivision/Section/Lot Number

9-16-24

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = <u>NTS</u>

