

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: <input checked="" type="radio"/> Y <input type="radio"/> N	Commercial Project: <input type="radio"/> Y <input type="radio"/> N
Code Enforcement Project No:	Permit No: SFD2408-0088
Project Name: New Single Family Dwelling	Owner: Paramount Homes Inc.
Project Address: 9904 Wishing Willow Dr. Raleigh, NC 27603	Suite No:
Date Inspected: 9-24-24	Contractor Name: Paramount Homes Inc.
Component Inspected: Footings	

Responsible Licensed NC Architect or NC Engineer

Name:	Mark E. Jones, PE
Firm Name:	
Phone Numbers:	Office: Mobile: 919-395-5618
Email Address:	markejonespe@gmail.com
Mailing Address:	6425 Glen Dean Ct. Raleigh, NC 27603


APPLICABLE CODE: 2018 NCRC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code


Describe Element/Component/Type of Inspection: *Footings for perimeter walls and interior piers were inspected for sizes, location, soil bearing (min. 2000psf), and clean of debris. Organic/soft soils were encountered in several areas and the contractor over excavated additional soils up to 36" until suitable soils were reached. The over excavations may be filled with stone or concrete. All footings met the requirements of the 2018 NCRC and were approved for concrete placement.

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.



Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.