



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/10/2025

SUBJECT: **SFD2408-0125**
SINGLE FAMILY DWELLING

To: ROBERTS THOMAS EARL II

Here are the results of all Inspections located at **3127 CHRISTIAN LIGHT RD:**

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL SFD MONO**

Scheduled Date/Time:

Completed Date/Time:

Inspector: Daniel L Floyd

Result:

Remarks:

Notes:

Inspection Type: ADDRESS

Scheduled Date/Time: 8/30/2024

Completed Date/Time: 9/3/2024

Inspector: GIS Bucket

Result: APPROVED

Remarks:

Notes: 3127 CHRISTIAN LIGHT RD FUQUAY VARINA 27526.
POST ADDRESS SIGN AT ROAD FOR LONG DRIVEWAY.

Inspection Type: UNDER SLAB TRADES

Scheduled Date/Time: 4/15/2025

Completed Date/Time: 4/15/2025

Inspector: Justin Ryan McLeod

Result: DISAPPROVED

Remarks:

Notes: Seal around sleeves Test low

Inspection Type: UNDER SLAB TRADES

Scheduled Date/Time: 4/16/2025

Completed Date/Time: 4/16/2025

Inspector: Justin Ryan McLeod

Result: APPROVED

Remarks:

Notes:

Inspection Type: FOOTING

Scheduled Date/Time: 4/16/2025

Completed Date/Time: 4/16/2025

Inspector: Justin Ryan McLeod

Result: CANCELLED

Remarks:

Notes: Please Come in the afternoon
Needed underslab trades.



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: MONO SLAB
Scheduled Date/Time: 4/17/2025
Completed Date/Time: 4/17/2025
Inspector: Scott Guy
Result: DISAPPROVED
Remarks:
Notes: Please come in the morning
Contractor to get third party due to compaction requirements.

Inspection Type: FOOTING
Scheduled Date/Time: 4/17/2025
Completed Date/Time: 4/17/2025
Inspector: Scott Guy
Result: CANCELLED
Remarks:
Notes: Scheduled incorrectly, this is a mono slab.

Inspection Type: MONO SLAB
Scheduled Date/Time: 4/22/2025
Completed Date/Time: 4/22/2025
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes: Engineer Letter in Attachments
Per third party

Inspection Type: ENV OPERATIONS PERMIT
Scheduled Date/Time: 5/20/2025
Completed Date/Time: 5/20/2025
Inspector: Reynold J Levocz
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 5/29/2025
Completed Date/Time: 5/29/2025
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks:
Notes: 1. Plumbing supply pressure low
2. Fill slab around washer drain and bathroom vanity drain
3. Drain test low
4. Need truss documents
Garage will need fire foaming at penetrations through top plate



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 6/4/2025
Completed Date/Time: 6/4/2025
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 6/4/2025
Completed Date/Time: 6/4/2025
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 8/27/2025
Completed Date/Time: 8/27/2025
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 8/27/2025
Completed Date/Time: 8/27/2025
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 9/2/2025
Completed Date/Time: 9/2/2025
Inspector: Daniel L Floyd
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL SFD MONO**

Scheduled Date/Time: 9/10/2025

Completed Date/Time: 9/10/2025

Inspector: Daniel L Floyd

Result: DISAPPROVED

Remarks:

Notes:

1. Holes in the garage ceiling need to have devices installed or holes covered with fire rated material 2. Need covers on low voltage boxes in the garage 3. Lights and fan in garage bath not working 4. Seal around garage bath sink drain 5. Missing covers on low voltage boxes and panel in garage closet 6. Missing weather stripping on small attic door 7. Gaps in Sheetrock above big attic door need to be sealed 8. Need air barrier around the top of the stairs walls to hold insulation in 9. Missing anti tip device for range 10. Seal around kitchen sink drain 11. Missing low voltage box covers in the house 12. Missing glass for shower 13. Backfill around water and sewer line 14. Electrical conduit sticking out of the panel on the back of the garage needs to be capped off and sealed around