



## CIVIL AND STRUCTURAL ENGINEERING SERVICES, PLLC

**SAMIR W. BAHHO, P.E.**

**Date: April 03, 2025**

John Fronk, Red Rock Builders  
1303 Olde Walker Mill Road,  
Apex, North Carolina 27502

Reference: Framing certification.  
Permit # SFD 2408-0127  
45 Pine Hill Court., Spring Lake, NC 28390

Woody

After review of the framing of the attic over living/bedroom for the house being built at the address: 45 Pine Hill Court, Spring Lake, NC. , I hereby certify that the 2-1 3/4x 11 7/8 rafters splices is ok and meets load bearing requirement of NCBC , Residential 2018. My seal and signature are affixed below for certification

For any further questions please call me or email me. My telephone number is (919) 621-0628. My email address is ba.casespllc@gmail.com

Sincerely,

Samir W. Bahho, PE (License # 16941)  
Business (License P-0537)



April 03, 2025

