



Connector Information					Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Header	Truss
●	MSH422	USP	6	Varies	10d/3"	10d/3"

GENERAL NOTES  
 1. ○ AVOID ALL PLUMBING DROP LOCATIONS  
 2. PB SERIES BEAMS ARE PROVIDED BY OTHERS

Products					
PlotID	Length	Product	Plies	Net Qty	
BM2 DROPPED	13' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	4	
BM1 DROPPED	11' 0"	1-3/4"x 11-7/8" LVL Kerto-S	2	2	
GDH DROPPED	21' 0"	1-3/4"x 14" LVL Kerto-S	2	2	
PB3 DROPPED	14' 0"	2x10 SPF No.2	2	2	
PB2 DROPPED	12' 0"	2x10 SPF No.2	2	2	
PB4 DROPPED	12' 0"	2x10 SPF No.2	2	2	
PB5 DROPPED	6' 0"	2x10 SPF No.2	2	2	

Truss Placement Plan  
 SCALE: NTS

▲ = Indicates Left End of Truss  
 (Reference Engineered Truss Drawing)  
 Do NOT Erect Truss Backwards

LOAD CHART FOR JACK STUDS  
 (BASED ON TABLES R502.5(1) & (2))  
 NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADERS

END REACTION (UP TO)	END REACTION (UP TO)	END REACTION (UP TO)	END REACTION (UP TO)
SPACING	SPACING	SPACING	SPACING
1700	2550	3400	
3400	5100	6800	
5100	7650	10200	
6800	10200	13600	
8500	12750	17000	
10200	15300		
11900			
13600			
15300			

<b>BUILDER</b>	Wellco Construction	<b>CITY / CO.</b>	Harnett County / Harnett
<b>JOB NAME</b>	Lot 11 Overhills Creek 2ND FL	<b>ADDRESS</b>	101 Onslow Court
<b>PLAN</b>	Plan #12	<b>MODEL</b>	FLOOR
<b>SEAL DATE</b>	Seal Date	<b>DATE REV.</b>	//
<b>QUOTE #</b>		<b>DRAWN BY</b>	Michael Turner
<b>JOB #</b>	J0424-1957	<b>SALES REP.</b>	Lenny Norris

**THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.**  
 These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSH-B1 and BCSH-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature: Michael Turner  
 Michael Turner

**comtech**  
**ROOF & FLOOR TRUSSES & BEAMS**  
 Reilly Road Industrial Park  
 Fayetteville, N.C. 28309  
 Phone: (910) 864-8787  
 Fax: (910) 864-4444