## Harnett County Department of Public Health

PERMIT # SFD 2409-0039 Operation Permit Mew Installation ☑ Septic Tank ☑ Nitrification Line ☐ Repair ☐ Expansion PROPERTY LOCATION: 580 Thomas Gage SUBDIVISION BECK WEED Grove LOT # 37 Name: (owner) KB Home System Installer: Day: 8 Basement with plumbing: Garage Number of Bedrooms \_\_ Type of Water Supply: 

Community Public 

Well Distance from well \_\_\_\_ Type TIGO EZ-Flow Types V and VI Systems expire in 5 years. System Type: 25% Reduction (In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal. This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization. 4-BR PERMIT CONDITIONS: Performance: System shall perform in accordance with Rule .1961. As required by Rule .1961. II. Monitoring: III. Maintenance: As required by Rule .1961. Other: Subsurface system operator required? Yes ☐ No ☐ If yes, see attached sheet for additional operation conditions, maintenance and reporting. IV. Operation: Other: □ Alarm □ H20Line □ D-Box Pump Following are the specifications for the sewage disposal system on the above captioned property. 1 Other Type III ( EZ-Flow Septic Tank: 1,000 gallons Pump Tank: 1,000 gallons width of depth of Type of system: 

Conventional Subsurface exact length No. of exact length 345 feet Drainage Field ditches French Drain Required: Date 2-27-25 Authorized State Agent