THIS IS A TRUSS PLACEMENT DIAGRAM (TPD) ONLY; NOT AN ENGINEERED DOCUMENT. Trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual truss design drawings (TDD's) for each truss design identified on the TPD. The Contractor is responsible for the temporary bracing of the roof and floor system, and requirements for the permanent restraint/bracing of truss systems may be met by following the methods outlined in ANSI-TPI 1-2014 - 2.3.3. The design of the support structure including but not limited to headers, beams, walls, and columns is also the responsibility of the building designer. For general guidance regarding installation and bracing, consult "Building Component Safety Information" (BCSI) available from the SBC Association (www.sbcacomponents.com). It is the responsibility of the General Contractor to verify that the provided component layout matches the final intended construction plans, loading conditions, and use. If they do not, it is the responsibility of the General Contractor to notify UFP and provide plans containing the latest specifications and eon-site during construction. DO NOT CUT, NOTCH, DRILL, OR OTHERWISE "REPAIR" MANUFACTURED TRUSSES IN ANY WAY WITHOUT PRIOR WRITTEN AUTHORIZATION BY A LICENSED PROFESSIONAL DESIGNATED BY UFP. The Framer is responsible to verify all dimensions, including adjusting member spacing within tolerances to allow for the drop and rise of plumbing/HVAC, unless noted otherwise. Truss-to-wall connections, if shown, are for uplift only and do not consider lateral loads. All connectors shown that are not truss-to-truss are suggestions only and are to be verified by the Building Designer or Engineer of Record for suitability to this specific atructure.



|--|

20 FACE MOUNT HANGER THA

THA422

A)

FLUSH LVL BEAM LIST											
Fab Type	Net Qty	Plies	Product	Length	PlotID						
MFD	3	3	1 3/4" x 14" 2.0E Microllam® LVL	14' 0"	2B-1						
MFD	2	2	1 3/4" x 14" 2.0E Microllam® LVL	12' 0"	2B-2						
MFD	1	1	1 3/4" x 14" 2.0E Microllam® LVL	6' 0"	2B-3						

r
INDICATES
IKUSS
UCAL

i.	
N.T.S	

R	OOF	ARE	A:	2650.52	ft²	sqft <b>RIDGE LINE:</b>	70.13 ft	VALLEY	LINES:	50.85 ft	HIP	LINES:	20.11	ft	THESE VALUES	ES ARE E ONLY
JOB #: 24	LAYOUT DATE ARCH DATE STRUC DATE	DATE -		REVISIONS DESCRIPTION -	DSN - -	SELMA PLAN 'TRADITIONAL' 2ND FLOOR	PBS		This dr Any ur written owners	drawing is property of UFP Site I unauthorized use of this document in permission is prohibited. UFP r riship of delivered product upon er of product must obtain UFP's au to any alteration or modification will not be held responsible thorized modifications done or cos ut prior written authorization from	Built, LLC. nent without relinquishes authorization of product; le for any sts incurred n UFP.	C. hout hes ry.	TrussTraxufpicom	UFP S A UFP IT Burlington, NC L Chesapeake VA L	TE BU NDUSTRIES COMPANY OCUST, NC	JILT
 081189F2	8-26-24 - -	AM		- - - - - -	-	319 DUNCAN'S CREEK ROAD LILLINGTON, NC 27546	NEW HOMI LOT 12 DUNCAN'S	ES INC. 27 CREEK	prior to UFP w unauthou without			uct; any rred		Clinton, NC C Conway, SC P Jefferson, GA S Customer Service	ooltewah, TN eearisburg, VA tanfield, NC (800) 476-9356	